


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction NW 1/4 SE 1/4 SE 1/4	Section number 32	Township number T 29 S	Range number R 30 SW	
2. Distance and direction from nearest town or city: of Copeland, Ks. Street address of well location if in city:	3. Owner of well: R.R. or street: Montezuma, Ks 67867					
4. Locate with "X" in section below: 	Sketch map:					
6. Bore hole dia. 26 in. Completion date 2-29-76 Well depth 365 ft.						
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary						
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other						
9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.0 lbs./ft. Dia. 16 in. to 366 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>						
10. Screen: Manufacturer's name NO SCREEN						
Type <input type="checkbox"/> Dia. <input type="checkbox"/> Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Perf. 200-365 ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> YES Size range of material <input type="checkbox"/> DOWN						
11. Static water level: mo./day/yr. 112 ft. below land surface Date 1-76						
12. Pumping level below land surfaces: 150 ft. after 2 hrs. pumping 775 g.p.m. 156 ft. after 1 hrs. pumping 1125 g.p.m. Estimated maximum yield 1125 g.p.m.						
13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date						
14. Well head completion: 12 Pitless adapter <input type="checkbox"/> Inches above grade						
15. Well grouted? <input checked="" type="checkbox"/> YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.						
16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>						
17. Pump: <input type="checkbox"/> Goulds US Pumps Manufacturer's name <input type="checkbox"/> Model number 14JHC HP 200 Volts <input type="checkbox"/> Length of drop pipe 220 ft. capacity 1400 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						19. Remarks: (Use a second sheet if needed)
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hinter Wilson Drilling 208 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address P.O. Box 1 Garden City, Ks Signed <input type="checkbox"/> Date 2-16-76 Authorized representative <input type="checkbox"/>						

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Chester Rexford
Gray County
11-9-75

Location: SE 32-29-30
450 feet East of Pivot

Test # 3

0	2	Top Soil
2	4	Brown Clay
4	48	Brown Sandy Clay
48	68	Fine to Med. Sand & Gravel
68	95	Brown Sandy Clay
95	106	Fine to Med. Sand & Gravel (Loose)
106	108	Coarse Gravel
108	110	Brown Clay
110	170	Fine to Med. Sand & Gravel (Loose)
170	182	Fine to Med. Sand & Gravel, Streaks of Clay (10%)
182	302	Fine to Med. Sand & Gravel (Loose)
302	310	Fine to Med. Sand & Fine Gravel (Little Tight)
310	320	Fine to Med. Sand, Streaks of Clay (10%) (Little Tight)
320	365	Fine to Med. Sand & Gravel (Loose)
365	410	Fine Sand & Brown, White & Gray Clay mixture (Tight)

T.D. 365'

Static Water Level: 154'