

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Gray	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 32	Township number T 29 S R 30 E	Range number 30
2. Distance and direction from nearest town or city: 3 1/2 mi. South of Copeland Kansas				3. Owner of well: Frank Clancy R.R. or street: Rural Route City, state, zip code: Copeland, Kansas 67837		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9</u> in. Completion date <u>3/14/76</u> Well depth <u>295</u> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material				9. Casing: Material <u>P145</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <u>g1</u> Surface <u>14</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u> </u> lbs./ft. Dia. <u>5</u> in. to <u>235</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>0.320</u>		
				10. Screen: Manufacturer's name <u>J E L</u> Type <u>PVC</u> Dia. <u>5"</u> Slot/gauze <u>1/16</u> Length <u>60</u> Set between <u>235</u> ft. and <u>295</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>Yes</u> Size range of material <u>1/8"</u>		
				11. Static water level: <u>163</u> ft. below land surface Date <u>3/14/76</u> mo./day/yr.		
				12. Pumping level below land surfaces: <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>60</u> g.p.m.		
				13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
				14. Well head completion: <u> </u> Pitless adapter <u>14</u> Inches above grade		
				15. Well grouted? <u>Yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>3</u> ft. to <u>13</u> ft.		
				16. Nearest source of possible contamination: ft. <u>190</u> Direction <u>NE</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		Well to be Completed By: Dunham Drilling Copeland, Kansas 67837		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T C W Water Well <u>142</u> Business name License No. Address Box 816 Liberal, KS Signed <u>[Signature]</u> Date <u>3/19/76</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WW-5