

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction SW/4 NW 1/4 NW 1/4	Section number 18	Township number T 29 S	Range number R 31 E/W
2. Distance and direction from nearest town or city: 5 E & 1 1/2 N of Sublette, KS Street address of well location if in city:			3. Owner of well: Martin Riphahn R.R. or street: R.R. City, state, zip code: Copeland, KS 67837		
4. Locate with "X" in section below: <div style="text-align: center;"> </div> Sketch map:			6. Bore hole dia. 26 in. Completion date 12/20/75 Well depth 408 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31 lbs./ft. Dia. 16 in. to 408 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188		
			10. Screen: Manufacturer's name W. A. Brown Mfg. Co. Type Leuvered Dia. 16 Slot/gauze 1/8" Length 80' Set between 390 ft. and 310 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/4" - 3/4"		
			11. Static water level: 196 ft. below land surface Date 12/20/75 mo./day/yr.		
(Use a second sheet if needed)			12. Pumping level below land surfaces: 229 ft. after <input type="checkbox"/> hrs. pumping 1420 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: none ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type observed Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
(Use a second sheet if needed)			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle DRIG & Supply 145 Business name License No. Address Box 639, Garden City, KS Signed E. L. Russell Date 1-15 Authorized representative		
			18. Elevation:		
			19. Remarks:		
			Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Martin Riphan DATE 11-17-75
STREET ADDRESS _____ TEST # 1 E-Log 485'
CITY & STATE Copeland, KS DRILLER Rector
COUNTY Haskell QUARTER NW SECTION 18 TOWNSHIP 29 RANGE 31

LOCATION 1320' south of NW corner of 1/4

				WELL LOCATION	
%	DRILLED		FOOTAGE	Description of Strata	Static Water Level
	From	Pay To			Proposed Well Depth
	0		2	Top soil	
	2		63	Brown clay	
	63		79	Sand fine to med coarse & med small gravel	
	79		90	Brown sandy clay	
	90		120	Sand fine to med coarse, small gravel & very fine sandy clay sts.	
80	120	162	362	Sand & gravel, fine to med coarse, small & some large, ragged in places, used lots of water. (mixed mud at 220')	
	362		370	Brown clay & limerock	
65	370	26	396	Sand & gravel fine to med coarse & small, loose, used lots of water, few clay & limerock sts.	
	396		400	Brown clay & limerock	
65	400	6	406	Sand fine to med coarse & med small gravel (loose) used water.	
	406		440	Clay & limerock	
	440		500	Brown sandy clay, limerock & coarse sand sts.	
TOTAL DEPTH OF WELL 408'					
Set up face South					
Pit on the west					
Pump motor set on south side of well, discharge facing west					

ARDEN CITY, KANSAS
HONE 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
IRRIGATION HEADQUARTERS

SUBLETTE, KANSAS
PHONE 675-4311

EST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****