


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County Haskell	Township name	Fraction SE $\frac{1}{4}$ , SE $\frac{1}{4}$ , SW $\frac{1}{4}$	Section number 21	Town number T 29S	Range number R 31 W
Distance and direction from nearest town or city: 3/4 S. & 1/2 E. of Tice Street address of well location if in city:				3 Owner of well: Jonas Koehn Address: Sublette, Kansas 67877		
Locate with "X" in section below: 				Sketch map:		
2 Type and color of material				4 Well depth: 370 ft. Date of completion 5-5-75 Well diameter 26 in.		
				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 Weight 36 lbs./ft. 16 in. to 370 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				8 Screen: Johnson Manufacturer Continuous Dia. 16" Type Slot/gauze .100 Length 30 ft. Set between 240 ft. and 260 ft. Fittings: 355 & 365 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4 to 1/8		
				9 Static water level: 180 ft. below land surface Date 2-18-75		
				10 Pumping level below land surfaces: 211 ft. after hrs. pumping 1440 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				12 Well head completion: 12 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite Depth: From 0 ft. to 10 ft.		
(use a second sheet if needed)				14 Nearest source of possible contamination: None Observed ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Johnston Model number 14CC HP Volts Length of drop pipe 305 ft. capacity 1440 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope Flat <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name License No. Address Box 639 Garden City, KS Signed [Signature] Date 5-5-75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

# DRILLERS TEST LOG

CUSTOMERS NAME Jonas Koehn DATE 1-31-75  
 STREET ADDRESS \_\_\_\_\_ TEST # 2 E. Log Hole  
 CITY & STATE Sublette, Kansas DRILLER Lee  
 COUNTY Haskell QUARTER SW SECTION 21 TOWNSHIP 29 RANGE 31

LOCATION 300 Ft. West of Test # 1

## WELL LOCATION

%	DRILLED from	FOOTAGE Pay to	Description of Strata	Static Water Level Proposed Well Depth
	0	3	Top soil	
	3	46	Brown clay and caliche st. Sand st.	
	46	62	Sand fine med. coarse.	
	46	62	Sand fine, med. coarse	
	62	74	Brown clay and sand st. Fine, med. coarse. Few broken rock. Loose in places.	
	74	85	Brown clay	
	85	117	Sand fine, med. coarse, small to med., gravel. Few large, few clay st. Used a lot of water.	
	117	126	Brown clay	
	126	160	Sand fine med. coarse, small to med. gravel. Few large, very few clay st. Used water. Few hard ledges.	
70	160	10 185	Sand fine, med. coarse, small to med. gravel. Some large, drilled tight in places. Used water.	
65	185	95 280	Sand fine med. coarse, small to few, med. gravel. Very few clay st. Used a lot of water.	
65	280	48 348	Sand fine, med. coarse, small to med. gravel. Very few large, few, white rock. very hard ledges, drilled like cemented ledges. Used pull down on them Used a lot of water. Hard ledges. Were 280 - 300'. A few 1 ledges from there on	
	348	352	Brown clay	
60	352	13 365	Sand fine med. coarse, some small gravel, and cemented ledges. Very hard. Used pulldown. Used a lot of water.	
	365	379	Brown and white clay and limerock. Very hard. Used pulldown	
	379	399	Sopstone, gray, with red st. one or two sandstone st.	
	399	418	Yellow and hard ledges.	
	418	420	Shale	
	186		TOTAL DEPTH OF WELL 370'	
			Set up facing West; pit on the North.	

GARDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS  
 PHONE 276-3278 IRRIGATION HEADQUARTERS PHONE 675-4311  
 TEST HOLES\*\*\*\*\*STOCK WELLS\*\*\*\*\*IRRIGATION AND INDUSTRIAL WELLS\*\*\*\*\*