


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Haskell	Township name Dudley	Fraction Mid. or NE 1/4	Section number 21	Town number XXXX T 29 S	Range number R 31 W
Distance and direction from nearest town or city: 1 mile east, 1/4 mile south, 1/4 mile west of Tice, Ks. Street address of well location if in city:			3 Owner of well: Gene Wedel Address: Copeland, Ks.			
Locate with "X" in section below: 			Sketch map:			4 Well depth: 367 ft. Date of completion 12-31-74 Well diameter 16 in.
2 Type and color of material			From To		5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
Top Soil			9		7 Casing: Material St. Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 300 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Brown clay			2 37		8 Screen: Manufacturer Johnson Division Type Galv. Dia. 16" Slot 100 Length 20' Set between 230 ft. and 250 ft.	
Brown sandy clay & brown clay			37 82		Perforations: 200-220, 290-330, 350-367 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 2 down	
Brown sandy clay, small stks. of fine to med. sand & gravel 30%			82 95		9 Static water level: 100 ft. below land surface Date 12-13-74	
Fine to med. sand & gravel 10% clay (Loose)			95 107		10 Pumping level below land surfaces: 191 ft. after 2 hrs. pumping 919 g.p.m. 201 ft. after 4 hrs. pumping 1321 g.p.m. Estimated maximum yield 1200 g.p.m.	
Fine to med. sand & gravel (Loose)			107 217		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
Brown Brown sandy clay & brown clay			217 245		12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 12 Inches above grade	
Blue clay			245 273		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Clay Puddle Depth: From 0 ft. to 10 ft.	
Blue & brown clay, stks. of gravel 30%			273 290		14 Nearest source of possible contamination: N/A ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Fine to med. sand & gravel 10% clay (sm. Hard Stks.)			352 367		15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Brown & gray clay w/brown & white rock(hard)			367 383		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 208 Business name License No. Address Box 493 Garden City, Ks. Signature <i>[Signature]</i> Date 3-20-75 Authorized representative <i>[Signature]</i>	
Brown, gray & yellow clay (Hard)			383 402			
Gray yellow & blue clay (Hard)			402 410			
(use a second sheet if needed)						
16 Remarks: elevation Good well. No possible contamination. Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5