


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Haskell	Township name NENE NE	Fraction 36	Section number T29S	Town number R31W	Range number
Distance and direction from nearest town or city: 1 mi. W. 3 mi. S. of Copeland, Kansas				3 Owner of well: M. Woodson		
Street address of well location if in city:				Address: Copeland, Kansas		
Locate with "X" in section below: N 		Sketch map:		4 Well depth: 290 ft. Date of completion 9-4-75 Well diameter 9 in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material RMP Height: <u>above/below</u> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 14 in. <u>well</u> Diam. Weight 320 lbs./ft. 5 in. to 230 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No — in. to — ft. depth		
2 Type and color of material		From	To	8 Screen: Manufacturer JEL Type RMP Dia. 5" Slot/gauze 1/16" Length 60' Set between 230 ft. and 290 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2"		
Overburden		0	173	9 Static water level: 173 ft. below land surface Date 9-4-75		
S + Gravel		173	287	10 Pumping level below land surfaces: — ft. after — hrs. pumping — g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield 50 g.p.m.		
Blue clay		287	290	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				12 Well head completion: 14" <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 3 ft. to 13 ft.		
				14 Nearest source of possible contamination: ft. 200 Direction SE Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation		(use a second sheet if needed)		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T&W Water Well 142 Business name License No. Address Box 816 Liberal, KS Signed C.W. Waggoner Date 9-4-75 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		Well to be completed by: Dunham Drilling Copeland, Kansas				