

15,203

Check: ☒ White Copy, ☐ Blue Copy, ☐ Pink Copy

MINTER-WILSON DRILLING CO.
INCORPORATED

**Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing**

Phone 620-276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

NAME	DAVE BRYANT
COUNTY	HASKELL
DATE	2-28-12

LOCATION: S 1/2 23-29-31 - FROM SOUTHEAST CORNER OF SUBLETTE
9 MILES EAST, 2-1/2 MILES NORTH &
300 FT. WEST

STATIC WATER LEVEL -

TEST # 2

0' TO 1' - TOP SOIL
1' TO 74' - BROWN SANDY CLAY WITH STRIPS OF WHITE ROCK
74' TO 78' - FINE TO MEDIUM SAND & GRAVEL
78' TO 85' - BROWN CLAY
85' TO 102' - BROWN SANDY CLAY WITH STRIPS OF SAND & GRAVEL
102' TO 300' - FINE TO MEDIUM SAND & GRAVEL
WITH LAYERS OF BROWN SANDY CLAY
300' TO 394' - FINE TO MEDIUM SAND & GRAVEL
394' TO 400' - CEMENTED SAND & GRAVEL
400' TO 406' - BROWN SANDY CLAY
406' TO 420' - FINE TO MEDIUM SAND & GRAVEL
WITH LAYERS OF BROWN SANDY CLAY - 25%
420' TO 432' - BROWN SANDY CLAY
432' TO 435' - FINE TO MEDIUM SAND
435' TO 455' - BROWN SANDY CLAY WITH STRIPS OF SAND & GRAVEL - 20%
455' TO 485' - BROWN SANDY CLAY WITH STRIPS OF WHITE ROCK
485' TO 500' - BROWN & YELLOW CLAY WITH 20% BROWN ROCK
500' TO 530' - SHALE - 250 PULL DOWN