

[illegible]

*The  
Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Janice McClure  
Haskell County  
9/2/97

Location: SW $\frac{1}{4}$  26-29-32 - From Sublette - 2-1/8ths miles east on Hwy. 56  
& 50 ft. south to well  
(1,000 ft. east and 600 ft. south of old well)

Static Water Level -

Test #3

0' to 2' - Top soil  
2' to 33' - Brown clay 01  
33' to 59' - Brown sandy clay 04  
59' to 85' - Fine to medium sand and gravel 17  
85' to 93' - Brown sandy clay 04  
93' to 263' - Fine to medium sand and gravel  
263' to 339' - Fine to medium sand and gravel - clay streak 17  
339' to 347' - Brown sandy clay 04  
347' to 386' - Fine to medium sand and gravel 17  
386' to 391' - Brown sandy clay 04  
391' to 397' - Fine to medium sand and gravel - small yellow rock mixed 17  
397' to 401' - Brown sandy clay 04  
401' to 409' - Fine to medium sand and gravel 17  
409' to 418' - Brown sandy clay - small sand strip  
418' to 436' - Brown sandy clay white rock sand stone mixed  
436' to 470' - Brown sandy clay 04  
470' to 508' - Brown clay  
508' to 522' - Yellow clay 01  
522' to 545' - Shale  
545' to 602' - Shale - tight  
602' to 624' - Shale - hard  
624' to 650' - Shale 19

RECEIVED

APR 20 1998

BUREAU OF WATER