

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction NW 1/4 SE 1/4 SE 1/4	Section number 7	Township number T 29 S R 33 E	Range number 33
2. Distance and direction from nearest town or city: 6 1/2 north from NE corner of Satanta, 3/4 east.			3. Owner of well: Leonard Ricker R.R. or street: City, state, zip code: Raymond Kansas -		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 6. Bore hole dia. 26 in. Completion date 6-30-77 Well depth 510 ft. 7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material steel Height: Above surface Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 511 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gauge No. 250		
5. Type and color of material			From	To	10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot 1/8" Length 20 ft. 40" Set between 370-390 ft. and 400-410, 490 Perf. 330-370 ft. and 390-400, 410-490 Gravel pack? yes Size range of material 1/2" down
					11. Static water level: 248 ft. below land surface Date 6-3-77
					12. Pumping level below land surfaces: 335 ft. after 2 hrs. pumping 1300 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 1200 g.p.m.
					13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
					14. Well head completion: Pitless adapter 12 inches above grade
					15. Well grouted? yes With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: N/A ft. Direction Type Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
					17. Pump: Goulds Not installed Manufacturer's name Goulds Model number 12M HP 200 Volts Length of drop pipe 480 ft. capacity 1300 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					(Use a second sheet if needed)
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. Address Box A Garden City, Ks. Signed [Signature] Date 7-30-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67816

LEONARD RICKER (OWNER)

SIG DORIS (TENANT)

HASKELL COUNTY

5-11-77

Location: SE 7-29-33 from NW corner of $\frac{1}{4}$ 1/8 mile south
250 Ft. east

Static Water Level- 290'

Test #3

0	1	Top soil
1	45	Brown clay
45	63	Med. to coarse gravel (Loose)
63	77	Brown clay
77	130	Med. to coarse gravel (Loose)
130	143	Brown sandy clay
143	170	Brown sandy clay streaks of gravel 30%
170	203	Fine to med. sand and gravel (Loose)
203	212	Brown clay
212	350	Fine to med. sand and gravel (Loose)
350	365	Fine to med. sand and gravel 20% clay (Loose)
365	393	Fine to med. sand and gravel (Loose)
393	396	Brown clay and white rock (Tight)
396	414	Fine to med. sand and gravel (Loose) (small hard streaks)
414	435	Brown clay and white rock
435	440	Fine to med.s and and fine gravel 10% clay (Loose)
440	449	Brown sandy clay
449	455	Fine to med.s and and fine gravel (Loose)
455	485	Fine to med. sand and fine gravel 15% clay (Loose)
485	489	Brown sandy clay
489	504	Fine to med. sand and gravel (Loose)
504	518	Brown gray and yellow clay (Hard)
518	530	Shale (Hard)

0-330 - *thin*
330-370 - *perf.*
370-390 - *screen*
390-400 - *perf.*
400-410 - *screen*
410-490 - *perf.*
490-500 - *screen*
500-510 - *perf.*

*Put foam from
345' - 359'*