


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Haskell	Township name	Fraction SE $\frac{1}{4}$, SE $\frac{1}{4}$, NW $\frac{1}{4}$	Section number 13	Town number T 29 S	Range number R 33 W
Distance and direction from nearest town or city: 2 $\frac{1}{2}$ S., 1/2 W of Old Sante Fe Street address of well location if in city:				3 Owner of well: Harry Wright Address: Sublette, Kansas 67877		
Locate with "X" in section below: N  W S E 1 Mile				Sketch map:		
2				4 Well depth: 473 ft. Date of completion 4-10-75 Well diameter 26 in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
See attachment				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. Weight 36 lbs./ft. 16 in. 473 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth		
				8 Screen: Manufacturer Johnson Type Continuous Dia. 16" Slot/gauze 100 Length 20' Set between 300 ft. and 320 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4 to 1/8		
				9 Static water level: 242 ft. below land surface Date 2-24-75		
				10 Pumping level below land surfaces: 291 ft. after hrs. pumping 1388 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				12 Well head completion: 12 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: None Observed ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Johnston Model number 14CC HP Volts Length of drop pipe 365 ft. capacity 1350 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation Topography: <input type="checkbox"/> Hill Flat <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name License No. Address Box 639 Garden City, KS Signed Zachary Henkle Date 4-10-75 Authorized representative		

DRILLERS TEST LOG

CUSTOMERS NAME	Harry Wright	DATE	2-7-75
STREET ADDRESS		TEST #	1 E.L.Hole 480'
CITY & STATE	Sublette, Kansas	DRILLER	Rector
COUNTY	Haskell	QUARTER	NW SECTION 13 TOWNSHIP 29 RANGE 33

LOCATION In SE corner of $\frac{1}{4}$

WELL LOCATION

Samples in on this test.

%	DRILLED from	Pay	FOOTAGE to	Description of Strata	Static Water Level Proposed Well Depth
	0		2	Top soil	
	2		45	Brown clay and caliche	
	45		130	Sand fine med. coarse, small coarse, small to large gravel. Very fine clay st.	
	130		135	Sandy clay and cemented sand, firm	
70	135	110	320	Sand fine med. coarse, small coarse, small to large gravel, rough and ragged. Used lots of water.	
	320		340	Brown sandy clay, sand, med. coarse.	
75	340	78	418	Sand fine med. coarse, small coarse and small gravel. Few cemented st. Loose. Used lots of water. Very good.	
	418		445	Brown clay and limerock and few sand st.	
65	445	12	457	Sand fine med. coarse, small coarse. Brown sandstone st. Fairly loose. Used lots of water.	
	457		465	Light blue clay and brown sandstone st.	
50	465	5	470	Brown sandstone and brown rock and clay. Used water.	
	470		480	Yellow clay and soapstone.	
		205			
				TOTAL DEPTH OF WELL	473 Ft.
				Face West; dig pit on North.	

ARDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS
HONE 276-3278 IRRIGATION HEADQUARTERS PHONE 7 675-4311
EST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****