


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CWW Inv. #14787

1. Location of well:		County Haskell	Fraction 1/4 1/4 SW 1/4	Section number 16	Township number T 29S S	Range number R 33W E/W
2. Distance and direction from nearest town or city: From Sublette Jct. go 2m. North - 4m West - 1m North and East to location.				3. Owner of well: C.M. Light Estate R.R. or street: Box 315 City, state, zip code: Liberal, Kansas 67901		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 7-6-78 Well depth 360 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Surface		0		2		9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 28 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.78 lbs./ft. Dia. 5 in. to 295 ft. depth Wall Thickness: inches or Dia. 5 in. to 360 ft. depth gage No. 265
Sandy clay		2		60		10. Screen: Manufacturer's name Saved perforation Type PVC Dia. 5" Slot/gauze 60' Set between 295 ft. and 355 ft. ft. and ft. Gravel pack? yes Size range of material 1/8-3/16
Fine sand		60		190		11. Static water level: 280 ft. below land surface Date 7-6-78 mo./day/yr.
Sandy clay		190		205		12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 20 g.p.m.
Fine sand & medium to large sand 60-40		205		340		13. Water sample submitted: yes No Date Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Sandy clay		340		350		14. Well head completion: Pitless adapter 28 Inches above grade
Blue clay		350		360		15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
(Use a second sheet if needed)						16. Nearest source of possible contamination: ft. Direction Type none Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carlile water Well Service 118 Business name License No. Address Box AA, Liberal, KS 67901 Signed Edward E. Means Date 7-13-78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5