


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Haskell	Fraction SW 1/4 SE 1/4 SW 1/4	Section number 29	Township number T 29 S	Range number R 33 E/W
2. Distance and direction from nearest town or city: 1 mile N, 5 W, of Sublette, Kansas Street address of well location if in city:				3. Owner of well: Bill Freedy R.R. or street: City, state, zip code: Satanta, Kansas		
X. Locate with "X" in section below: N W E S 1 Mile Sketch map:  200' N of SW corner of SE 1/4, Sec. 29, T29S, R33W, Haskell County, Kansas.				6. Bore hole dia. 9 in. Completion date _____ Well depth 400 ft. 7/30/76 7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material galvanneal Weight: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 16 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 340 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 320 10. Screen: Manufacturer's name J & L Type slot Dia. 5" Slot/gauze 1/8" Length 40' Set between 340 ft. and 360 ft. 380 ft. and 400 ft. Gravel pack? yes Size range of material 2.5mm 11. Static water level: unk mo./day/yr. _____ ft. below land surface Date _____ 12. Pumping level below land surface not pumped _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m. 13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____ 14. Well head completion: _____ Pitless adapter 6 Inches above grade 15. Well grouted? yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft. 16. Nearest source of possible contamination: unk ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co., Inc. 102 Business name License No. Address Garden City, Kansas Signed [Signature] Date 1 Dec 76 Authorized representative		
5. Type and color of material		From		To		
Top soil		0		2		
Fine sand		2		15		
Tan clay		15		79		
Fine to coarse sand medium gravel		79		101		
Fine sand & tan clay		101		110		
Fine to coarse sand medium gravel		110		276		
Fine to coarse sand medium gravel with						
yellow clay		276		283		
Fine to coarse sand medium gravel		283		325		
Blue & Green clay with small amount of gravel		325		341		
Fine to coarse sand medium gravel		341		362		
Blue & green clay		362		377		
Fine to coarse sand medium to coarse gravel		377		420		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5