


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Haskell	Fraction SE 1/4 SW 1/4 SW 1/4	Section number 29	Township number T 29 S	Range number R 33 E
2. Distance and direction from nearest town or city: 3 1/2 N. from the NE corner of Satanta, 1 1/2 east.				3. Owner of well: Bill Preedy R.R. or street: Route 1 City, state, zip code: Satanta, Kansas 67870		
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. 26 in. Completion date 4-26-77 Well depth 490 ft.		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material steel Height: Above caselaw Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 491 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
				10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/gauze 1020 Length 400 ft. Set between 400 ft. and 440 ft. Perf: 300-400 ft. and 440-490 ft. Gravel pack? yes Size range of material 2" down		
				11. Static water level: 267 ft. below land surface Date 4-26-77 12. Pumping level below land surfaces: 267 ft. after 6 hrs. pumping 1600 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1600 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name California Western Model number 120 HP 120 Volts <input type="checkbox"/> Length of drop pipe 400 ft. capacity 2 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name Box A Garden City, Ks. License No. 9-30-77 Address Box A Garden City, Ks. Date 4-26-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

TEST HOLE LOG

Wagner's

Box 10, Ulysses, Kansas 67880

Water Wells & Test Holes

Phone (316) 356-2396

Date 3-21-1977Test No. 1Qtr. SW Sec. 29Twp. 29 Rge 33Co. HaskellLand Owner Bill PreedyAddress Satanta, Kansas

CONSOLIDATED-SALINA

75' W of old well

FOOTAGE	Description of Strata
0 - 20	Surface and fine sand
20 - 60	Brown clay
60 - 80	Brown sandy clay
80 - 440	Coarse sand
440 - 500	Fine sand and gyp: Blue shale 490-500
	Hole at 500 ft.