

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

MI-1023

DRILLERS TEST LOG

CUSTOMERS NAME Kirby Clawson DATE 5-20-76
 STREET ADDRESS _____ TEST # 2 E. Log
 CITY & STATE Satanta, KS DRILLER Livingston
 COUNTY Haskell QUARTER SW SECTION 4 TOWNSHIP 29 RANGE 34

LOCATION 1,000 ft. west of the NE corner of the SW $\frac{1}{4}$

%	DRILLED FOOTAGE			WELL LOCATION	
	From	Pay	To	Description of Strata	Static Water Level _____ Proposed Well Depth _____
	0		3	Top soil	
	3		57	Brown sandy clay and fine sand	
	57		167	Sand fine to med., small to large gravel, cemented ledges	
	167		173	Brown clay	
	173		190	Sand fine to med. coarse, small to med. gravel	
	190		210	Brown clay and lime rock ledges	
	210		226	Sand fine to med. coarse, small gravel	
	226		330	Brown clay, few lime rock ledges and fine sand st.	
	330		340	Sand fine small and clay st.	
35	340	15	355	Sand fine to med. coarse, small gravel	
	355		369	Brown clay	
50	369	7	375	Sand fine to med. coarse, small to med. gravel	
	375		380	Brown clay	
75	380	20	400	Sand fine to med. coarse, small to large gravel	
65	400	10	410	Sand fine to med. coarse, small gravel	
	410		416	Brown clay	
55	416	11	427	Sand fine to med. coarse, small gravel	
	427		440	Brown clay	
50	440	8	448	Sand fine to med. coarse, small gravel	
	448		520	Brown clay, lime rock ledges and few sand st.	
70	520	37	557	Sand fine to med. coarse, small to med. brown gravel cemented in places	
	557		567	Brown and yellow clay	
	567		587	Weathered shale	
Very Good	587		647	Dakota, loose, used lots of water	
	647		648	Limestone	
	648		653	Red bed	
		168			
				TOTAL DEPTH OF WELL 650 FT.	
				Set up south	
				Dig pit on the west	