## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		number	Township number Range number
1. Location of well:	Haskell	SW 1/4 SW 1/4 SW 1/4	7		T 29 S R 34 E
2. Distance and direction from nearest town or city:  6 miles north, 6 K.R. or st Street address of well location if in city: Satanta, Ks.  City, stat					Howard Pickens Satanta, Ks. 67870
4. Locate with "X" in section below: Sketch map:					6. Bore hole dia. — 1. Completion date
N				7548	Well depth 515 ft. 10-20-77  7Cable tool X_RotaryDrivenDugHollow rodJettedBoredReverse rotary  8. Use: X_DomesticPublic supplyIndustryIrrigationAir conditioningStock
S 1 Mile 1 Mile				LawnOil field waterOther  9. Casing: Materies tyren bleight: Above or below Threaded Welded Surface in. RMP Red Weight lbs./ft. Dia. 5 in. ta 395 ft. depth Wall Thickness: inches or	
5. Type and color of material				То	Dia in. to ft. depth gage No 320
Surface Very fine sand w/clay strips				2 23	Type styrene Dia. 10 120/ 5' Slot/gauze 1/16 Length 120' Set between 395 ft. and 515 ft.
Sandy clay			23	50	ft. andft.  Gravel pack? _X Size range of materialft.
Medium to coarse sand & gravel			50	95	11. Static water level: mo./day/yr. 245 ft. below land surface Date 10-20-77
Brown clay			95	105	12. Pumping level below land surfaces: NA
Medium to coarse sand & gravel			105	210	ft. after hrs. pumping g.p.m ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.
Medium to coarse sand w/clay breakers			210	364	13. Water sample submitted: mo./day/yr.  Yes No Date
Embedded sand w/cloose strips & clay breakers				418	14. Well head completion:
Sandy clay w/very fine to fine sand strips				445	X Pitless adapter 18 Inches above grade  15. Well grouted? X
Very fine to fine sand w/sandrock & sandy clay				470	With: X Neat cement Bentonite Concrete Nepth: From 0 ft. to ft.
Fine to medium sand, sandrock & sandy clay				489	16. Nearest source of possible contamination:  ft. 250 Direction SOUTH Type Sewer
Cemented sand w/loose strips			489	515	Well disinfected upon completion? x Yes 11neNo  17. Pump: X Not installed
					Manufacturer's name
			-		Length of drop pipe ft. capacityg.p.m. Type:
	<u>-</u>		-		Submersible Turbine Reciprocating
(Use a second sheet if needed)					Centrifugal Other 5
18. Elevation: 12 Remarks:  Topography:  Topography:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
Hill  X Slope					Houck Bros. Drilling Co. 164 Business name License No. Address Box 487, Ulysses, Ks.
Upland Valley					Signed M. Burne Date 72/27/7 7