

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction NW 1/4 SW 1/4 NE 1/4	Section number 21	Township number T 29	Range number S 34W E/W
2. Distance and direction from nearest town or city: 10 miles east, 3 1/2 south & 1/2 east of Hickok Street address of well location if in city:			3. Owner of well: Faye Tunis R.R. or street: P. O. Box 281 City, state, zip code: Satanta, Kansas 66566		
4. Locate with "X" in section below: N W E S 1 Mile NW NE SW SE 1 Mile		Sketch map: 10 East Hickok 3 1/2 South 1/2 East NW 1/4, SW 1/4, NE 1/4		6. Bore hole dia. 5 5/8 Completion date _____ Well depth 1568 ft.	
5. Type and color of material		From	To	7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored _____ Reverse rotary _____	
Surface and fine sand		0	15	8. Use: _____ Domestic _____ Public supply _____ Industry _____ <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other _____	
Sandy clay with fine sand strips		15	34	9. Casing: Material <u>steel</u> Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP _____ PVC _____ Weight <u>3425</u> lbs./ft. Dia. <u>16</u> in. to <u>568</u> ft. depth Wall thickness: inches or _____ Dia. _____ in. to _____ ft. depth Case No. _____	
Fine to medium to coarse sand with clay breaker		34	176	10. Screen: Manufacturer's name _____ Johnson Type <u>Galvanized</u> Dia. <u>16"</u> Slot/size <u>100x100</u> Length <u>50'</u> Set between <u>354</u> ft. and <u>474</u> ft. <u>474</u> ft. and <u>504</u> ft. Gravel pack? <u>yes</u> Size range of material <u>down</u>	
Brown sandy clay with medium sand strips		176	215	11. Static water level: _____ mo./day/yr. <u>261</u> ft. below land surface Date <u>5/28/76</u>	
Medium to coarse sand with clay breakers		215	405	12. Pumping level below land surfaces: <u>275</u> ft. after <u>2</u> hrs. pumping <u>900</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>900</u> g.p.m.	
Embedded sand, lime shale with clay breakers		405	446	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____	
Fine to medium sand with clay breakers		446	496	14. Well head completion: _____ Pitless adapter _____ <u>12</u> inches above grade	
Medium to coarse sand with clay breakers		496	560	15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite _____ Concrete _____ Depth: From <u>0</u> ft. to <u>10</u> ft.	
Sand stone- lost circulation at 560		560	575	16. Nearest source of possible contamination: ft. _____ Direction <u>in field</u> type _____ Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No _____	
Brown shale		575	600	17. Pump: Not installed Manufacturer's name <u>Goulds</u> Model number <u>14M</u> HP <u>200</u> Volts _____ Length of drop pipe <u>360</u> ft. capacity <u>1300</u> g.p.m. Type: _____ Submersible _____ <input checked="" type="checkbox"/> Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____	
(Use a second sheet if needed)					
18. Elevation: Topography: _____ Hill <input checked="" type="checkbox"/> Slope _____ Upland _____ Valley	19. Remarks: Drilling sub-contracted to : Minter Wilson Drilling- License no. 208 Garden City, Kansas *Lakewood-slot: 125x66 Set between 274 to 354, 374 to 474, & 504 to 588			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. K. I. Drilling co., Inc. 263 Business name _____ License No. _____ Address P. O. Box 669 M. Joyce Burke 6/9/76 Authorized representative _____ Date _____	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5