

1 LOCATION OF WATER WELL:	Fraction	Section Number	Township Number	Range Number
County: HASKELL	C 1/4 SE 1/4 NE 1/4	9	T 29 S	R 34W E/W

Distance and direction from nearest town or city street address of well if located within city?

6 1/2 MILES NORTHWEST SANTANTA

2 WATER WELL OWNER: HUGOTON ENERGY CO.	#1A-9 CLAWSON MLP
RR#, St. Address, Box #: 301 N MAIN, STE. 1900	Board of Agriculture, Division of Water Resources
City, State, ZIP Code: WICHITA, KS 67202	Application Number: 940511

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL: 480 ft. ELEVATION:
	Depth(s) Groundwater Encountered 1. 230 ft. 2. ft. 3. ft. WELL'S STATIC WATER LEVEL 230 ft. below land surface measured on mo/day/yr 12-13-94 Pump test data: Well water was 250 ft. after 1 hours pumping 80 gpm Est. Yield 80 gpm: Well water was ft. after hours pumping gpm Bore Hole Diameter 11 in. to 480 ft., and in. to ft. WELL WATER TO BE USED AS: 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well Was a chemical/bacteriological sample submitted to Department? Yes No X ; If yes, mo/day/yr sample was submitted Water Well Disinfected? Yes X No

5 TYPE OF BLANK CASING USED:	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued X Clamped
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)
2 PVC	4 ABS	7 Fiberglass	Welded
Blank casing diameter 6 in. to 480 ft., Dia	in. to ft., Dia	in. to ft., Dia	in. to ft.
Casing height above land surface 24 in., weight 2.902 lbs./ft. Wall thickness or gauge No. 280 SDR 21			
TYPE OF SCREEN OR PERFORATION MATERIAL:	7 PVC	10 Asbestos-cement	
1 Steel	3 Stainless steel	5 Fiberglass	8 RMP (SR)
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS
SCREEN OR PERFORATION OPENINGS ARE:	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
1 Continuous slot	3 Mill slot	6 Wire wrapped	9 Drilled holes
2 Louvered shutter	4 Key punched	7 Torch cut	10 Other (specify)
SCREEN-PERFORATED INTERVALS:	From 360 ft. to 480 ft., From ft. to ft.		
GRAVEL PACK INTERVALS:	From 340 ft. to 480 ft., From ft. to ft.		

6 GROUT MATERIAL:	1 Heat cement	2 Cement grout	3 Bentonite	4 Other HOLE PLUG
Grout Intervals: From ft. to 20 ft., From ft. to ft., From ft. to ft.				
What is the nearest source of possible contamination:	1 Septic tank	4 Lateral lines	7 Pit privy	10 Livestock pens
2 Sewer lines	5 Cess pool	8 Sewage lagoon	11 Fuel storage	15 Abandoned water well
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	12 Fertilizer storage	16 Other (specify below)
Direction from well? Southeast			13 Insecticide storage	How many feet? 135

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	2	CLAY			
2	6	CLAY			
6	32	SANDY CLAY			
32	49	CLAY & SANDY CLAY			
49	203	SAND			
203	283	CLAY			
283	378	SAND			
378	421	MED. GRAVEL & SAND			
421	464	SANDY CLAY			
464	480	CLAY			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 12-13-94 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. KWCL-430 This Water Well Record was completed on (mo/day/yr) 12-13-94 under the business name of HOWARD DRUG CO. BOX 806 BEAVER, OK 73932 by (signature) <i>Howard</i>
--

INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water, Topeka, Kansas 66620-0001. Telephone: 913-296-5545. Send one to WATER WELL OWNER and retain one for your records.