The Professionals

MINTER-WILSON DRILLING CO. Comple

and Domestic
Water Systems
Applete Installation

INCORPORATED

Phone 276-8269 . P.O. Box A . GARDEN CITY, KANSAS 67846

MINTER-WILSON ULYSSES MELVIN SIMPSON GRANT COUNTY 7-6-81

/-0-8

Location: NEt, SEt, NEt 1-29-35 - Satanta and Riggs Jct. 1 E, t S. West side of road by pond

Static Water Level -

		· · · · · · · · · · · · · · · · · · ·
Test #1	Dispo	sal Well
(0)	7	Top Soil
7	49	Brown Clay
49	70	Fine to Med. Sand and Gravel
70	140	Fine to Med. Sand and Gravel Streak of Coarse
	•	Gravel Loose
140	202	Med. Coarse Gravel
202	222 ·	Brown Sandy Clay
222	232	Med. Coarse Gravel
232	245	Fine to Med. Sand and Gravel

T.D. 248'