

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Grant	Fraction SW 1/4 NE 1/4 NW 1/4	Section number 28	Township number T 29 S R	Range number 35	(EW)
2. Distance and direction from nearest town or city: 10 east, 4 south, east of the four way stop at Ulysses, South into yard			3. Owner of well: Howard Lighty		R.R. or street: RFD 1		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 9 3/4 in. Completion date 12/3/78		Well depth 395 ft.		
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material styrene <input checked="" type="checkbox"/> Right <input checked="" type="checkbox"/> Above or below <input type="checkbox"/> Threading <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 355 ft. depth Wall Thickness <input type="checkbox"/> inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 320		10. Screen: Manufacturer's name Sunflower Type styrene Dia. 5" Slot/gauze 1/16" Length 40 Set between 355 ft. and 395 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4"		
Surface			From 0 To 2		11. Static water level: 220 ft. below land surface Date 11-22-78 mo./day/yr.		
Medium to coarse sand and gravel			2 22		12. Pumping level below land surfaces: 230 ft. after 10 hrs. pumping 14 g.p.m.		
Brown clay w/fine sand strips			22 41		____ ft. after ____ hrs. pumping ____ g.p.m.		
Medium to coarse sand w/clay breakers			41 123		Estimated maximum yield 22 g.p.m.		
Gray clay			123 145		13. Water sample submitted: ____ Yes <input checked="" type="checkbox"/> No Date ____ mo./day/yr.		
Medium to coarse sand w/clay strips			145 197		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade		
Gray and blue clay			197 211		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Medium to coarse sand w/clay breakers			211 222		16. Nearest source of possible contamination: ft. 135 Direction NW Type sewer line		
Gray and blue clay w/medium sand strips			222 266		Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Medium to coarse sand w/clay breakers			266 280		17. Pump: <input checked="" type="checkbox"/> Not installed		
Sandy clay, white clay w/fine sand strips			280 310		Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____		
Sandy clay and white clay w/fine sand strips tight			310 350		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name License No. Address Box 487, Ulysses, Ks. Signed Malcolm M. Beard Date 12/30/78 Authorized representative		
Sandy clay and white clay w/fine sand strips SANDY			350 385				
Medium to coarse sandrock w/clay strips			385 395				
(Use a second sheet if needed)							
18. Elevation:		19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Directions are by hiway 160 east.		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name License No. Address Box 487, Ulysses, Ks. Signed Malcolm M. Beard Date 12/30/78 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5