


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Grant	Fraction NW 1/4 NW 1/4 NE 1/4	Section number 6	Township number T 29 S R	Range number 36
2. Distance and direction from nearest town or city: from standard service station 3 1/2 miles east, Ulysses			3. Owner of well: Alvin Valardes R.R. or street: Ulysses, Ks. 67880 City, state, zip code:		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 9 3/4" Completion date _____ Well depth 397 ft. 3/7/79
Surface			0-	2	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay & fine sand			2	25	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Brown clay			25	175	9. Casing: Material styrene Height: Above or below 48 in. <input checked="" type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 48 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 5 in. to _____ ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth 320 gage No.
Brown & blue clay			175	270	10. Screen: Manufacturer's name Lakewood Type styrene Dia. 5" Slot/gauze 1/16" Length 40 <input checked="" type="checkbox"/> Met between 350 ft. and 390 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2"
Brown clay and fine sand			270	325	11. Static water level: _____ mo./day/yr. 255 ft. below land surface Date 3-10-79
Lime shells hard			325	335	12. Pumping level below land surfaces: 285 ft. after 3 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 g.p.m.
Clay w/medium sand			335	380	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Medium sand			380	390	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 14 Inches above grade
Clay w/medium sand			390	400	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Clay w/rock shells			400	415	16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
(Use a second sheet if needed)					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drilling Co. 164 Business name License No. _____ Box 487, Ulysses, Ks. 67880 Address Signed M. Beard Date 8/22/79 Authorized representative		

29
 36
 W
 E
 - 10
 Sec
 1/4
 1/4
 1/4
 NW
 NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5