

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Grant	Fraction SW 1/4 SE 1/4 SW 1/4	Section number 8	Township number T 29 S R	Range number 37 E/W
2. Distance and direction from nearest town or city: from four way stop at Ulysses 2 miles south, 2 west, Street address of well location if in city: 1 south			3. Owner of well: Dan Sullivan R.R. or street: 202 N. Hickok City, state, zip code: Ulysses, Ks. 67880		
4. Locate with "X" in section below: <div style="text-align: center;"> </div>			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. <u>27</u> in. Completion date _____ Well depth <u>488.10</u> ft. <u>8/31/78</u>
Surface					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Sandy clay, fine sand & lime shells			2	24	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Brown sandy clay w/fine sand strips			24	48	9. Casing: Material <u>Steel</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface _____ in. RMP _____ PVC _____ Weight <u>36.8</u> lbs./ft. Dia. <u>16</u> in. to <u>266.6</u> depth/Wall Thickness: <u>1/8</u> in. or Dia. _____ in. to _____ ft. depth/gage No. <u>219</u>
Fine to medium sand w/clay breakers			48	64	10. Screen: Manufacturer's name Lakewood Pipe of Texas
Brown sandy clay			64	196	Type <u>steel</u> Dia. <u>16"</u> Slot/gauze <u>3/16"</u> Length <u>122.4'</u> Set between <u>326.6</u> ft. and <u>408.10</u> ft. <u>448.10</u> ft. and <u>488.10</u> ft.
Brown gummy clay w/sandy clay strips			196	218	Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 x 5/8</u>
Brown sandy clay w/very fine to medium sand str.			218	229	11. Static water level: _____ mo./day/yr. <u>302</u> ft. below land surface Date <u>9/1/78</u>
Brown sandy clay			229	282	12. Pumping level below land surfaces: <u>390</u> ft. after <u>34.4</u> hrs. pumping <u>700</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>1000</u> g.p.m.
Fine to coarse sand w/gravel strips & clay break.			282	333	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Brown sandy clay, W/very fine sandy strips & lime shells			333	344	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>20</u> Inches above grade
Very fine to medium sand some coarse clay breakers and lime shells			344	358	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
Brown sandy clay, very fine to fine sand strips, lime shells and sand rock strips			358	430	16. Nearest source of possible contamination: ft. _____ Direction _____ Type <u>field</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Fine to coarse sand w/clay breakers			430	464	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Brown clay, sandy clay, strips of gravel and sandstone and rock strips			464	491	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. License No. <u>164</u> Business name _____ Address <u>Box 487, Ulysses, Ks.</u> Signed <u>M. Beard</u> Date <u>9/11/78</u> Authorized representative
Blue shale, sandstone strips, tight brown broken shale			491	501	
Blue & gray shale & brown broken shale			501	534	
18. Elevation:		19. Remarks: W. A. Brown Screen set between 266.6 ft. and 326.6 then again at 408.10 ft and 448.10			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

29
 37
 8
 Sec
 1/4
 1/4
 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5