

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

NC NW NE

1. Location of well:		County Grant	Fraction Lots 3 & 4 North Fork Heights <small>1/4 1/4 1/4</small>	Section number 9	Township number T 29 S R 37	Range number 37	
2. Distance and direction from nearest town or city: 1/4 west of Ulysses, Ks. <small>Street address of well location if in city:</small>			2 miles south		3. Owner of well: Charles Neatherlin R.R. or street: RFD 3 City, state, zip code: Ulysses, Ks. 67880		
4. Locate with "X" in section below:				Sketch map:		6. Bore hole dia. 9 1/4 in. Completion date _____ Well depth 350 ft. 9-28-77	
						7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material				From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Surface				0	2	9. Casing: Material styrene <input checked="" type="checkbox"/> Above <input type="checkbox"/> below Threaded _____ Welded _____ Surface 12 in. RMP _____ pvc glued Weight _____ lbs./ft. Dia. 5 in. to 300 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 320	
Sandy clay				2	103	10. Screen: Manufacturer's name Sunflower Type styrene Dia. 5" Slot/gauze 1/16 Length 50 Set between 300 ft. and 350 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4"	
Brown clay				103	157	11. Static water level: _____ mo./day/yr. 226 ft. below land surface Date 8-23-77	
Blue clay				157	219	12. Pumping level below land surfaces: 246 ft. after 26 hrs. pumping _____ p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.	
Sandy clay				219	281	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
Coarse Coarse sand & gravel w/clay breakers				281	310	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade	
Sandy clay w/fine to medium sand strips				310	350	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.	
						16. Nearest source of possible contamination: ft. 150ft Direction west Type sewer line Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No	
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)							
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name License No. Address Box 487, Ulysses, Ks. Signed M. Beard Date 11-17 Authorized representative			
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley							

29
 320
 9
 1/4
 1/4
 1/4