

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County GRANT Fraction SE 1/4 NE 1/4 NE 1/4 Section number 4 Township number T 29 S R 38 E 10 Range number	
2. Distance and direction from nearest town or city: 6 mi. 1/4 So of Ulysses - Street address of well location if in city:	
3. Owner of well: Bob Faulds (Tenant) R.R. or street: Route 2, Box 149A City, state, zip code: Ulysses, Kansas 67880 (See Test Log)	
4. Locate with "X" in section below: Sketch map:	
5. Type and color of material	
6. Bore hole dia. 26 in. Completion date 3-31-77 Well depth 545 ft.	
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material steel Height: Above 0-12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 546 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250	
10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot gauge Length 20 ft. Set between 380-430 ft. and 460-480 ft. Perf: 280-300 ft. and 340-380 430-460 ft. Gravel pack? yes Size range of material 3/4" down	
11. Static water level: 265 ft. below land surface Date 3-18-77 mo./day/yr.	
12. Pumping level below land surfaces: 326 ft. after 6 hrs. pumping 1000 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1000 g.p.m.	
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
16. Nearest source of possible contamination: N/A ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Goulds Model number 1AN HP 200 Volts Length of drop pipe 420 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winter-Wilson Drlg. Co. 208 Business name License No. Address Box A Garden City, Ks. Signed [Signature] Date 3-30-77 Authorized representative	

480-545

T
R
M
Sec
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

TEST HOLE LOG

Test No. 4

Wagner's

Box 10, Ulysses, Kansas 67880

Water Wells & Test Holes

Phone (316) 356-2396

Date 2-7-1977

Qtr. NE Sec. 4

Twp. 29 Rge. 38

Co. Grant

Land Owner J. A. Kaywood & Barns (Owners)

Address 3103 East English

Wichita, Kansas 67200

800' S of E corner

CONSOLIDATED-SALINA

FOOTAGE	Description of Strata
0 - 20	Surface and brown clay
20 - 120	Brown clay
120 - 140	Fine clay
140 - 240	Brown clay: Coarse sand 230-240
240 - 300	Coarse sand & gravel
300 - 340	Brown clay: Some gyp, fine sand
340 - 360	" " : Sand 345-355: Br. clay 355-360
360 - 380	Br. clay & fine sand, 40%
380 - 400	Sand & brown clay: Coarse sand & gravel 390-400
400 - 420	Coarse sand & gravel, loose
420 - 440	" " " " " " : Sand, br. cemented clay 425-440
440 - 460	Brown shale, hard
460 - 480	Brown shale & loose Dakota, 80%
480 - 500	Brown shale & some Dakota
500 - 520	Blue & brown shale, hard
520 - 540	Brown shale: Br. shale & Dakota, med. loose
540 - 560	Br. shale & Dakota, med. loose: Brown shale & redbed 545-560

0 - 280	plain
280 - 300	screen
300 - 340	plain
340 - 380	perf.
380 - 425	screen
425 - 460	perf.
460 - 480	screen
480 - 545	perf.