

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Grant</b>	Fraction <b>SW 1/4 NE 1/4 SW 1/4</b>	Section number <b>9</b>	Township number <b>T 29 S R 38 E/W</b>	Range number
2. Distance and direction from nearest town or city: <b>5 west, 3 south, 1 1/2 west, 1/4 north, 1/4 west of Ulysses, KS.</b> Street address of well location if in city:			3. Owner of well: <b>Virgil Johnson</b> R.R. or street: City, state, zip code: <b>Ulysses, Kansas 67880</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>26</b> in. Completion date <b>7-31-75</b> Well depth <b>485</b> ft.	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From		9. Casing: Material <b>Steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>486</b> ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. <input type="checkbox"/>	
				10. Screen: Manufacturer's name <b>No Screen</b> Type <input type="checkbox"/> Dia. <b>16</b> Slot/gauze <input type="checkbox"/> Length <b>125</b> <del>Set between</del> Perf: <b>220 # 280</b> <b>360-485</b> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <input type="checkbox"/>	
				11. Static water level: <input type="checkbox"/> mo./day/yr. <b>188</b> ft. below land surface Date <b>7-5-75</b>	
				12. Pumping level below land surfaces: <b>255</b> ft. after <b>3</b> hrs. pumping <input type="checkbox"/> g.p.m. <b>690</b> ft. after <b>3</b> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <b>700</b> g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>	
				14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <b>N/A</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter-Wilson Drilling 208</b> Business name License No. Address <b>Box A, Garden City, KS</b> Signed <i>[Signature]</i> Date <b>3-26-76</b> Authorized representative	
18. Elevation:	19. Remarks:  <div style="text-align: right;">(Use a second sheet if needed)</div>				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 29  
 R 38  
 E  
 -9  
 Sec  
 1/4  
 1/4  
 1/4  
 SW NE SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Pho. 276-8269 P.O. Box 493 • GARDEN CITY, KANSAS 67846

Vergil Johnson  
Grant County  
6-25-75

Location: 100 ft. south of Test #1 SW $\frac{1}{4}$  9-29-38

Test #2

0	2	Top soil
2	47	Brown sandy clay
47	50	Blue clay
50	95	Brown sandy clay
95	115	Fine to med. sand
115	140	Brown sandy clay
140	163	Fine to med. sand (tight)
163	221	Brown sandy clay
221	235	Fine to med. sand, gravel (loose)
235	258	Brown sandy clay
258	264	Med. sand
264	274	Brown sandy clay
274	283	Fine to med. sand & gravel
283	290	Brown sandy clay
290	306	Brown clay mixed with brown rock, gravel streak (hard)
306	322	Brown sandy clay with gravel streak
322	360	Brown sandy clay
360	390	Fine to med. sand, 20% clay
390	395	Fine to med. sand and gravel (tight)
395	408	Fine to med. sand, 20% clay (tight)
408	444	Med. sand & coarse gravel
444	454	Brown sandy clay
454	485	Brown rock, sandstone, some gravel
485	500	Brown, yellow clay

Static