

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Grant	Fraction SE 1/4 SE 1/4 NE 1/4	Section number 23	Township number T 29 S R 38 E	Range number 38
2. Distance and direction from nearest town or city: \$ 4 miles west 4 3/8 miles south of Standard Service Station at Ulysses			3. Owner of well: John Siebert R.R. or street: 101 So. Maxwell City, state, zip code: Ulysses, Kansas 67880		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: <i>Septic tank 140 ft - well</i> <i>House</i> <i>Round Top</i>		
5. Type and color of material			From	To	6. Bore hole dia. 9 1/4 in. Completion date 3/28/78 Well depth 450 ft.
Surface			0	2	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Fine to medium sand w/gray clay			2	30	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Brown clay			30	70	9. Casing: Material Styrene Height (Above or below) Threading <input type="checkbox"/> Welded <input type="checkbox"/> Surface 16 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 420 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 320
Fine to medium sand w/clay breakers			70	108	10. Screen: Manufacturer's name Sunflower Type styrene Dia. 5" Slot/gauze 1/16" Length 30 Set between 420 ft. and 450 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4"
Brown clay			108	131	11. Static water level: <input type="checkbox"/> mo./day/yr. 101 ft. below land surface Date 8/25/78
Brown and gray clay w/lime shells			131	140	12. Pumping level below land surfaces: 111 ft. after 3 hrs. pumping 16 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 50 g.p.m.
Blue clay			140	155	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
Brown clay w/very fine sand strips			155	183	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade
Brown clay w/very fine sand strips			183	259	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 10 ft.
Brown sandy clay w/fine to medium sand strips			259	270	16. Nearest source of possible contamination: ft. 140 Direction west Type septic tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Brown sand clay w/very fine to fine sand strips			270	302	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Brown sandy clay w/very fine sand strips			302	420	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. 164 Houck Bros. Drilling Co. 301 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Box 487, Ulysses, KS. Signed M. Beard Date 4/5/78 Authorized representative
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

29
 38
 23
 SE
 SE
 NE
 1/4
 1/4
 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5