

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>STANTON</b>	Fraction <b>NE<sup>4</sup> SW 1/4 NE<sup>4</sup></b>	Section number <b>2</b>	Township number <b>T 29 S R 39</b>	Range number <b>39</b>
2. Distance and direction from nearest town or city: <b>1 south 1 east</b> <b>1 north of Big Bow</b> <small>Street address of well location if in city:</small>			3. Owner of well: <b>Lynlo Land Corp.</b> R.R. or street: <b>3122 N. Walnut</b> City, state, zip code: <b>Hutchinson, Ks 67501</b>		
4. Locate with "X" in section below:		Sketch map:			
5. Type and color of material		From	To		6. Bore hole dia. <b>26</b> in. Completion date <b>5-21-76</b> Well depth <b>455</b> ft.
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
					9. Casing: Material <b>Steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>456</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>219</b>
					10. Screen: Manufacturer's name <b>Johnson Division</b> Type <b>Galv.</b> Dia. <b>16"</b> Slot/gauze <b>100</b> Length <b>20'</b> Set between <b>400</b> ft. and <b>420</b> ft. <b>Perf.</b> <b>260-400</b> ft. and <b>420-455</b> ft. Gravel pack? <b>yes</b> Size range of material <b>2-3" Down</b>
					11. Static water level: <input type="checkbox"/> mo./day/yr. <b>212</b> ft. below land surface Date <b>11-11-76</b>
					12. Pumping level below land surfaces: <b>315</b> ft. after <b>2</b> hrs. pumping <b>850</b> g.p.m. <b>369</b> ft. after <b>4</b> hrs. pumping <b>1300</b> (same air) g.p.m. Estimated maximum yield <b>1300</b> g.p.m.
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
					14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade
					15. Well grouted? <b>yes</b> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.
					16. Nearest source of possible contamination: <b>N/A</b> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Peerless Inc</b> Model number <b>12MB</b> HP <b>125</b> Volts _____ Length of drop pipe <b>440</b> ft. capacity <b>1800</b> gal. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter Wilson Drilling 208</b> Business name <b>P.O. Box A Garden City Ks</b> License No. _____ Address _____ <i>[Signature]</i> <b>7-16-76</b> Signed _____ Date _____ Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

29 29 W 2 NESW NE 1/4 1/4 1/4

The Professionals

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation and Domestic Water Systems Complete Installation and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

NEWLIN REYNOLDS  
SEWARD COUNTY  
2-24-76

LOCATION: NE 1/4 2-29-39  
From N.E. Corner Of 1/4, 450 Feet West

STATIC WATER LEVEL: 155'

### TEST #6

0	1	Top Soil
1	25	Brown Clay
25	65	Brown Clay & White Rock (Tight)
65	76	Fine To Med. Sand & Fine Gravel (15%) Clay (Loose)
76	80	Brown Clay
80	104	Brown Sandy Clay (35%) Fine Sand
104	125	Brown Sandy Clay
125	155	Fine To Med. Sand (30%) Clay
155	170	Fine To Med. Sand & Fine Gravel (10%) Clay (Loose)
170	185	Brown Sandy Clay, Streaks Of Fine To Med. Sand (3%)
185	218	Brown Sandy Clay
218	260	Brown Clay
260	275	Fine To Med. Sand & Gravel (35%) Clay
275	337	Fine To Med. Sand & Fine Gravel (10%) Clay (Loose)
337	350	Fine To Med. Sand & Gravel (20%) Clay (Fairly Loose)
350	365	Fine To Med. Sand & Fine Gravel (Loose)
365	425	Fine To Med. Sand & Fine Gravel (10%) Clay (Loose)
425	455	Fine To Med. Sand & Gravel, Brown R. (10%) Clay , Small Hard Streaks

### TEST #6

455	472	Fine To Med. Sand & Gravel (20%) Clay (Tight)
472	485	Brown, Gray, Yellow & Red Clay With Brown Rock (Hard)