

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Stanton	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 12	Township number T 29 S R 39	Range number 1/W
2. Distance and direction from nearest town or city: 1 south of Big Bow, 1 1/2 east, 300 ft. south, 200ft. east			3. Owner of well: Don Lorlowick R.R. or street: RFD 1 City, state, zip code: Johnson, Ks. 67855		
4. Locate with "X" in section below: <div style="text-align: center;"> </div>			6. Bore hole dia. 26 in. Completion date 12-27-76 Well depth 562 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 563 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		
			10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16" Slot/gauge <input type="checkbox"/> Length 20 ft. Set between 395 ft. and 435 ft. Perf: 280-395 ft. and 435-562 ft. Gravel pack? Yes Size range of material 2" down		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 175 ft. below land surface Date 11-17-76		
			12. Pumping level below land surfaces: 277 ft. after 3 hrs. pumping 1200 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1200 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
			15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: N/KA ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Peerless - FMC Model number 12MB HP 200 Volts <input type="checkbox"/> Length of drop pipe 480 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 208 Business name License No. Address Box A Garden City, Ks. Signed <i>[Signature]</i> Date 12-27-76 Authorized representative		

T
R
W
M
Sec
1/4
1/4
1/4

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

DON LORLEVIC
 STANTON COUNTY
 11-2-76

534 562 Con't Small hard skt.
 562 575 Brown gray blue and red clay hard
 T.D. 562

Location: NE 12-29-39 1 mile south of Big Box 1 1/2 miles
 east 300 Ft. south 200 Ft. east
 Static Water Level - 260'

230 plain
 115 Perf
 40 Screen
 127 Perf

Test #2	1	1
9	1	Top soil
1	67	Brown clay
67	78	Fine to med. sand and fine gravel 15% clay
78	245	Brown clay
245	260	Fine to med. sand and fine gravel 30% clay
		Loose
260	309	Fine to med. sand and fine gravel 10% clay
		Loose
309	335	Brown sandy clay
335	362	Fine to med. sand and fine gravel 30% clay
		Light
362	380	Fine to med. sand and fine gravel 40% clay
		Tight
380	395	Fine to med. sand and fine gravel 20% clay
		Tight
395	410	Fine to med. sand and fine gravel 10% clay
		Loose
410	422	Fine to med. sand and gravel Loose
422	440	Fine to med. sand and gravel 10% clay tight
		Hard stks.
440	458	Fine to med. sand and gravel with brown rock
		15% clay Loose
458	470	Fine to med. sand and gravel with brown rock
		30% clay Loose Small Hard Stks.
470	500	Brown gray and yellow clay mixed with blue
		shale light(Mixed with Brown "rock")
500	509	Brown yellow & blue shale 20% brown
		rock hard
509	534	Brown rock 40% clay loose(small hard stks.)
534	562	Brown tan and blue clay stks. of brown rock
		Fairly lo