


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stanton	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 33	Township number T 29 S R 39	Range number 39
2. Distance and direction from nearest town or city: 2 west, 1/2 north of Big Bow, Ks. Street address of well location if in city:				3. Owner of well: Leon Kilgore R.R. or street: Johnson, Ks. 67855 City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9 1/4</u> in. Completion date <u>2/21/79</u> Well depth <u>260</u> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Surface		0		3		9. Casing: Material <u>plastic</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>(18)</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <u>5</u> in. to <u>220</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <u>sch. 40</u>
Clay		3		60		10. Screen: Manufacturer's name <u>Peerless</u> <u>Plastic</u> Type <u>plastic</u> Dia. <u>5"</u> Slot/gauze <u>1/16</u> Length <u>40'</u> Set between <u>220</u> ft. and <u>260</u> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4"</u>
Clay and lime w/fine sand		60		97		11. Static water level: <u>130</u> ft. below land surface Date <u>2/23/79</u> mo./day/yr.
Medium to coarse sand w/small clay breakers		97		183		12. Pumping level below land surfaces: <u>140</u> ft. after <u>6</u> hrs. pumping <u>14</u> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <u>30</u> g.p.m.
Clay and fine sand		183		198		13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.
Coarse sand w/small clay breakers		198		261		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>18</u> inches above grade
Gray clay, yellow chalk w/sandstone strips		261		280		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
(Use a second sheet if needed)						16. Nearest source of possible contamination: ft. <u>200</u> Direction <u>NE</u> Type <u>septic tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name <u>Box 487, Ulysses, Ks.</u> License No. <u>164</u> Address <u>Ulysses, Mo.</u> Signed <u>Melvin M. Beard</u> Date <u>6/29/79</u> Authorized representative		