

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Stanton</b>	Fraction <b>NE 1/4 SW 1/4 NE 1/4</b>	Section number <b>2</b>	Township number <b>T 29 S</b>	Range number <b>R 40 E/W</b>
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
<b>From the SE corner of Johnson, 4 3/4 E., 1/2 S.</b>			<b>Ted Julian Johnson, Ks. 67855</b>			
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 			
5. Type and color of material			From	To	6. Bore hole dia. <u>30</u> in. Completion date <u>4-5-77</u> Well depth <u>434</u> ft.	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>435</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>435</u> ft. depth gage No. <u>250</u>	
					10. Screen: Manufacturer's name <u>Johnson</u> Type <u>galv.</u> Dia. <u>16"</u> Slot/gauge <u>20</u> Length <u>20</u> ft. Set between <u>400</u> ft. and <u>420</u> ft. Perf. <u>230-400</u> ft. and <u>420-434</u> ft. Gravel pack? <u>yes</u> Size range of material <u>2" down</u>	
					11. Static water level: <u>190</u> ft. below land surface Date <u>4-5-77</u> mo./day/yr.	
					12. Pumping level below land surfaces: <u>213</u> ft. after <u>2</u> hrs. pumping <u>800</u> g.p.m. <u>220</u> ft. after <u>4</u> hrs. pumping <u>1400</u> g.p.m. Estimated maximum yield <u>1400</u> g.p.m.	
					13. Water sample submitted: <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date	
					14. Well head completion: <u>12</u> Pitless adapter <u>12</u> Inches above grade	
					15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
					16. Nearest source of possible contamination: <u>N/A</u> ft. <u>        </u> Direction <u>        </u> Type <u>        </u> Well disinfected upon completion? <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/>	
					17. Pump: <u>Not installed</u> Manufacturer's name <u>Goulds</u> Model number <u>147</u> HP <u>200</u> Volts <u>        </u> Length of drop pipe <u>240</u> ft. capacity <u>1800</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:			19. Remarks:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			(Use a second sheet if needed)			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter-Wilson Drilling Co. 208</u> Business name License No. <u>        </u> Address <u>Box A Garden City, Ks.</u> Signed <u>        </u> Date <u>5-30-77</u> Authorized representative			

29  
400  
W  
2  
NESUNE  
1/4 1/4 1/4

*The Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

TED JULAIN  
STANTON COUNTY  
2/23/77

Location: NE 2-29-40 north west corner of 4

Static Water Level- 165'

Test #8

0	1	Top soil
1	7	Clay and sand
7	23	Brown clay
23	31	Fine sand
31	61	Brown clay
61	66	Fine to med. sand and gravel Loose
66	80	Brown clay
80	93	Fine to med. sand and gravel 20% clay
93	164	Brown clay
164	170	Fine sand
170	180	Fine to med. sand and gravel 10% clay Loose
180	137	Brown clay
197	198	Fine to med. sand and gravel 15% clay Loose
198	232	Brown clay
232	245	Fine to med. sand and gravel 10% clay Loose
245	263	Brown sandy clay
263	277	Fine to med. sand and gravel 10% clay Loose
277	290	Brown sandy clay
290	305	Fine to med. sand and gravel 15% clay (Fairly Loose)
305	320	Fine to med. sand and gravel Loose 10% clay
320	323	Brown sandyclay
323	434	Fine to med. sand and gravel Loose
434	455	Browngray and yellow clay Hard

T.D. 434'