

USE TYPEWRITER OR BALL-
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County STATON	Fraction SE 1/4 NW 1/4 SE 1/4	Section number 15	Township number T 29 S R 40	Range number 40
2. Distance and direction from nearest town or city: 6 west 3 1/2 south of Big Bow				3. Nearest town or city: Dwight Mitchell		
Street address of well location if in city:				R.R. or street: RR		
				City, state, zip code: Johnson, Ks. 67855		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 3-31-76		
<div style="text-align: center;">N 1 Mile W E S 1 Mile</div> <p>1 Mile</p>				Well depth 177 ft.		
5. Type and color of material		From		To		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 178 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. <input type="checkbox"/>
						10. Screens: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze 100 Length 20' Set between 380-390 ft. and 455-465 ft. Perf. 240-380 ft. and 390-455 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2" Dren
						11. Static water level: <input type="checkbox"/> mo./day/yr. 186 ft. below land surface Date 1-26-76
						12. Pumping level below land surfaces: 192 ft. after 3 hrs. pumping 1400 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 1400 g.p.m.
						13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Customer Furnished old pump. Set at 250'		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name Address P.O. Box A Garden City, Ks. Signed Madene St. James Date 8-19-76 Authorized representative		

Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Dwight Mitchell
Stanton County
12-22-75

Location: SE 15-29-40
Northeast Corner of $\frac{1}{4}$

Test # 4

0	1	Top Soil
1	23	Brown Clay
23	54	Brown Clay & White Rock (Tight)
54	63	Brown Clay
63	95	Fine to Med. Sand & Gravel (Loose)
95	112	Brown Clay
112	125	Fine to Med. Sand & Gravel (Hard Streaks)
125	140	Brown Clay, 35% Gravel (Loose)
140	183	Fine to Med. Sand & Gravel (Loose)
183	200	Brown Clay (Tight)
200	215	Fine to Med. Sand & Gravel, 10% Clay (Small Hard Streaks)
215	397	Fine to Med. Sand & Gravel (Loose)
397	420	Brown Sandy Clay & Brown Clay (Tight)
420	428	Fine to Med. Sand & Gravel (Loose)
428	455	Brown Sandy Clay
455	477	Fine to Med. Sand & Gravel (Loose)
477	485	Brown, Gray & Red Clay & Brown Rock (Hard)