

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620


1 Location of well:	County <b>Stanton</b>	Township name	Fraction <b>NE<math>\frac{1}{4}</math> NW<math>\frac{1}{4}</math> NW<math>\frac{1}{4}</math></b>	Section number <b>3</b>	Town number <b>29S</b>	Range number <b>41W</b>
---------------------	--------------------------	---------------	---	----------------------------	---------------------------	----------------------------

Distance and direction from nearest town or city: **Hiway intersection at Johnson, Ks. : 1 mile south, 1 $\frac{1}{2}$  miles west**  
Street address of well location if in city:

3 Owner of well: **Frank Smith**  
Address: **% Bob Irwin**  
**Johnson, Kansas**

Locate with "X" in section below:

Sketch map:



4 Well depth: **412** ft. Date of completion **7/23/75**  
Well diameter **27** in.

5  Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary

6 Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Commercial  
 Test well

7 Casing: Material **stl.** Height: **(above)** below  
Threaded  Welded  Surface **12** in.  
Diam. **16"** Weight **36.8** lbs./ft. **1**  
**0** in. to **268.1** depth! Drive shoe?  Yes  No  
**0** in. to **0** ft. depth!

2	Type and color of material	From	To
	Surface	0	2
	Brown and sandy clay w/very fine sand strips	2	61
	Medium to coarse sand (lost circulation)	61	75
	Brown & sandy clay w/sand strips	75	105
	Medium to coarse sand	105	173
	Brown clay w/sand strips	173	182
	Embedded sand	182	191
	Medium to coarse sand	191	297
	Brown & yellow shale w/very fine sand strips	297	342
	Fine to coarse sand	342	364
	Brown shale w/very fine to fine sand sand 80%	364	409
	Yellow chalk, sandrock & brown shale	409	420
	(use a second sheet if needed)		

8 Screen: **Johnson Lakewood**  
Manufacturer \_\_\_\_\_  
Type **stl.** Dia. **16"**  
 Slot gauze **3/16** Length **2"** slot  
Set **from** \_\_\_\_\_ ft. and \_\_\_\_\_ ft. \_\_\_\_\_  
Fittings:  
Gravel pack  Yes  No Size range of material \_\_\_\_\_

9 Static water level:  
**264** ft. below land surface Date **6-28-75**

10 Pumping level below land surfaces:  
**340** ft. after **12** hrs. pumping **400** g.p.m.  
**340** ft. after **24** hrs. pumping **400** g.p.m.  
Estimated maximum yield **500** g.p.m.

11 Water sample submitted:  
 Yes  No Date \_\_\_\_\_

12 Well head completion:  
 Pitless adapter  **2** inches above grade

13 Well grouted?  Yes  No  
 Neat cement  Bentonite  \_\_\_\_\_  
Depth: From **0** ft. to **10** ft.

14 Nearest source of possible contamination: **NA**  
ft. \_\_\_\_\_ Direction \_\_\_\_\_ Type \_\_\_\_\_  
Well disinfected upon completion?  Yes  No

15 Pump:  Not installed  
Manufacturer's name \_\_\_\_\_  
Model number \_\_\_\_\_ HP \_\_\_\_\_ Volts \_\_\_\_\_  
Length of drop pipe \_\_\_\_\_ ft. capacity \_\_\_\_\_ g.m.p.  
Type:  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

16 Remarks: elevation **Johnson Screen set from 268.1 to 298.1 ft.**  
**Lakewood set from 298.1 ft. to 412 ft.**

17 Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
**Houck Bros. Drlg. Co. 164**  
Business name License No. \_\_\_\_\_  
Address **Box 487, Ulysses, Ks.**  
Signed **Maeki Beard** Date **8/27/75**  
Authorized representative

Topography:

- Hill  
 Slope  
 Upland  
 Valley