

1 LOCATION OF WATER WELL: County: <u>Kingman</u>	Fraction <u>NE</u> $\frac{1}{4}$ <u>NW</u> $\frac{1}{4}$ <u>NW</u> $\frac{1}{4}$	Section Number <u>1</u>	Township Number T <u>29</u> S	Range Number R <u>5</u> EW
---	---	----------------------------	----------------------------------	-------------------------------

Distance and direction from nearest town or city street address of well if located within city?

6N, 1 1/4 E. Norwich

2 WATER WELL OWNER: Jim SkillehRR#, St. Address, Box # : RRCity, State, ZIP Code : Cheney, Ks. 67025

Board of Agriculture, Division of Water Resources

Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

N	
X	
W	E
SW	SE
S	

4 DEPTH OF COMPLETED WELL: 67 ft. ELEVATION:Depth(s) Groundwater Encountered 1. 28 ft. 2. 58 ft. 3. 58 ft.WELL'S STATIC WATER LEVEL 28 ft. below land surface measured on mo/day/yr 2-19-87Pump test data: Well water was 28 ft. after 58 hours pumping 28 gpmEst. Yield 28 gpm: Well water was 28 ft. after 58 hours pumping 28 gpmBore Hole Diameter 10 in. to 67 ft. and 67 in. to 67 ft.WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)

2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well

Was a chemical/bacteriological sample submitted to Department? Yes ✓ No ✓; If yes, mo/day/yr sample was submittedWater Well Disinfected? Yes ✓ No ✓

5 TYPE OF BLANK CASING USED:

1 Steel

3 RMP (SR)

5 Wrought iron

8 Concrete tile

CASING JOINTS Glued Clamped

2 PVC

4 ABS

6 Asbestos-Cement

9 Other (specify below)

Welded

7 Fiberglass

Threaded

Blank casing diameter 5 in. to 47 ft. Dia. 18 in. weight 18 lbs./ft. Wall thickness or gauge No. SDR26Casing height above land surface 18 in. weight 18 lbs./ft. Wall thickness or gauge No. SDR26

TYPE OF SCREEN OR PERFORATION MATERIAL:

1 Steel

3 Stainless steel

5 Fiberglass

7 PVC

10 Asbestos-cement

2 Brass

4 Galvanized steel

6 Concrete tile

8 RMP (SR)

11 Other (specify)

9 ABS

12 None used (open hole)

SCREEN OR PERFORATION OPENINGS ARE:

1 Continuous slot

3 Mill slot

5 Gauzed wrapped

8 Saw cut

11 None (open hole)

2 Louvered shutter

4 Key punched

6 Wire wrapped

9 Drilled holes

SCREEN-PERFORATED INTERVALS:

From 47 ft. to 67 ft. From 67 ft. to 67 ft.From 47 ft. to 67 ft. From 67 ft. to 67 ft.GRAVEL PACK INTERVALS: From 14 ft. to 67 ft. From 67 ft. to 67 ft.From 14 ft. to 67 ft. From 67 ft. to 67 ft.

6 GROUT MATERIAL:

1 Neat cement

2 Cement grout

3 Bentonite

4 Other

Grout Intervals: From 3 ft. to 14 ft. From 14 ft. to 14 ft. From 14 ft. to 14 ft.

What is the nearest source of possible contamination:

1 Septic tank

4 Lateral lines

7 Pit privy

10 Livestock pens

14 Abandoned water well

2 Sewer lines

5 Cess pool

8 Sewage lagoon

11 Fuel storage

15 Oil well/Gas well

3 Watertight sewer lines

6 Seepage pit

9 Feedyard

12 Fertilizer storage

16 Other (specify below)

13 Insecticide storage

Direction from well? SouthHow many feet? 200

FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
0	2	Soil			
2	11	Clay			
11	19	Sand/clay			
19	67	Shale			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed (2) reconstructed, or (3) plugged under my jurisdiction and wascompleted on (mo/day/year) 2-19-87 and this record is true to the best of my knowledge and belief. KansasWater Well Contractor's License No. 395 This Water Well Record was completed on (mo/day/yr) 5-22-87under the business name of Craig Roberts Co. by (signature) Craig Roberts

INSTRUCTIONS: Use typewriter or ball point pen, PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Environmental Geology Section, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.