

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kingman	Fraction 1/4 SW 1/4 SW 1/4	Section number 29	Township number T 29 S	Range number R 5W E/W
2. Distance and direction from nearest town or city: 3 miles West of Norwich and 2 1/4 North, Street address of well location if in city: East side of road. Norwich, Kansas			3. Owner of well: Clarence Ward R.R. or street: Rt. #1 Box 74 City, state, zip code: Norwich, Kansas		
4. Locate with "X" in section below: Sketch map: <div style="text-align: center;"> </div>			6. Bore hole dia. 11 in. Completion date 7-25-78 Well depth 45 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Styrene Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 45 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 200		
			10. Screen: Manufacturer's name Sunflower plastic Type styrene Dia. 5" Slot/gap .06 Length 15' Set between 30 ft. and 45 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/4-1/8"		
Topsoil			From	To	11. Static water level: 15 ft. below land surface Date 7-25-78 mo./day/yr.
Clay			3	10	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.
Fine sand			10	32	13. Water sample submitted: <input type="checkbox"/> Yes <input type="checkbox"/> No Date
Red shale			32	45	14. Well head completion: capped <input type="checkbox"/> Pitless adapter 12 inches above grade
					15. Well grouted? yes 1-2 fine sand mix With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft.
					16. Nearest source of possible contamination: ft. 400 Direction South Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No tank
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 7-27-78 Authorized representative
18. Elevation:	19. Remarks: Flat ground				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 29 S 5W E/W
 Sec 29
 1/4 1/4 1/4