

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County KINGMAN	Fraction NW 1/4 SW 1/4 NE 1/4	Section number 2	Township number T 29	Range number S 7 R 7 W E (M)
2. Distance and direction from nearest town or city: Street address of well location if in city:		55 3 1/2 E OF KINGMAN, KS		3. Owner of well: JOE KREHBI R.R. or street: City, state, zip code: KINGMAN, KS		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: WATER WELL X DRAINAGE		6. Bore hole dia. 30 in. Completion date 26 APR 77 Well depth 52 ft.		
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
SOIL		0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
CLAY, TAN		2	6	9. Casing: Material STL Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 32 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188		
SAND, FINE		6	9	10. Screen: Manufacturer's name W.A. BROWN Type FLFLO Dia. 16" Slot/gauze 1/8 Length 20' Set between 32 ft. and 52 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 - 1/2		
SAND, FINE TO COARSE		9	20	11. Static water level: <input type="checkbox"/> mo./day/yr. 8 ft. below land surface Date <input type="checkbox"/>		
SAND, FINE TO COARSE & FINE TO MOD GRAVEL (LOOSE)		20	30	12. Pumping level below land surfaces: 40 ft. after 1 hrs. pumping 307 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
SAND, FINE TO COARSE & FINE TO COARSE GRAVEL (LOOSE)		30	47	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
CLAY, TAN		47	48	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
SAND, FINE TO COARSE & FINE TO COARSE GRAVEL (LOOSE)		48	52	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
SAND, RED		52	60	16. Nearest source of possible contamination: NONE ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: Manufacturer's name ELWAY Model number <input type="checkbox"/> HP 30 Volts <input type="checkbox"/> Length of drop pipe 50 ft. capacity 380 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CENTRAL WELL & PUMP 325 Business name License No. Address 1215 TAYLOR PROTT Signed J. J. Monomich Date 26 APR 77 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		5' X 10' SLAB WAS POURED AT SURFACE				