

1 LOCATION OF WATER WELL: County: <b>Kingman</b>	Fraction <b>NE</b> 1/4 <b>Ne</b> 1/4 <b>SW</b> 1/4	Section Number <b>21</b>	Township Number <b>T 29 S</b>	Range Number <b>R 9 W E/W</b>
---	---	-----------------------------	----------------------------------	----------------------------------

Distance and direction from nearest town or city street address of well if located within city?

**1/2 W 1/2 S of Willowdale**

2 WATER WELL OWNER: <b>Mike Gillen</b> RR#, St. Address, Box #: <b>9640 SW 110 Ave</b> City, State, ZIP Code: <b>Zenda, Kas. 67159</b>	Board of Agriculture, Division of Water Resources Application Number:
--	--

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL: <b>52</b> ft. ELEVATION:
--	---

Depth(s) Groundwater Encountered 1. **22** ft. 2. ft. 3. ft.

WELL'S STATIC WATER LEVEL **18** ft. below land surface measured on mo/day/yr **7-10-97**

Pump test data: Well water was ft. after hours pumping gpm

Est. Yield **10** gpm: Well water was ft. after hours pumping gpm

Bore Hole Diameter **9** in. to **52** ft. and in. to ft.

WELL WATER TO BE USED AS:

5 Public water supply	8 Air conditioning	11 Injection well
1 Domestic	3 Feedlot	6 Oil field water supply
2 Irrigation	4 Industrial	7 Lawn and garden only
		10 Monitoring well

12 Other (Specify below)

Was a chemical/bacteriological sample submitted to Department? Yes ☐ No ☒ If yes, mo/day/yr sample was submitted

Water Well Disinfected? Yes ☐ No ☒

5 TYPE OF BLANK CASING USED:	5 Wrought iron	8 Concrete tile	CASING JOINTS: <u>Glued</u> Clamped
------------------------------	----------------	-----------------	-------------------------------------

1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)	Welded
2 <u>PVC</u>	4 ABS	7 Fiberglass		Threaded

Blank casing diameter **5** in. to **46** ft. Dia. in. to ft. Dia. in. to ft.

Casing height above land surface **18** in. weight lbs./ft. Wall thickness or gauge No. **.210**

TYPE OF SCREEN OR PERFORATION MATERIAL:	7 PVC	10 Asbestos-cement
---	-------	--------------------

1 Steel	3 Stainless steel	5 Fiberglass	8 <u>RMP (SR)</u>	11 Other (specify)
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS	12 None used (open hole)

SCREEN OR PERFORATION OPENINGS ARE:

1 Continuous slot	3 Mill slot	5 Gauzed wrapped	8 Saw cut	11 None (open hole)
2 Louvered shutter	4 Key punched	6 Wire wrapped	9 Drilled holes	
		7 Torch cut	10 Other (specify)	

SCREEN-PERFORATED INTERVALS: From **46** ft. to **52** ft. From ft. to ft. From ft. to ft.

GRAVEL PACK INTERVALS: From **23** ft. to **52** ft. From ft. to ft. From ft. to ft.

6 GROUT MATERIAL:	1 Neat cement	2 Cement grout	3 <u>Bentonite</u>	4 Other
-------------------	---------------	----------------	--------------------	---------

Grout Intervals: From **3** ft. to **23** ft. From ft. to ft. From ft. to ft.

What is the nearest source of possible contamination:

1 Septic tank	4 Lateral lines	7 Pit privy	10 Livestock pens	14 Abandoned water well
2 Sewer lines	5 Cess pool	8 Sewage lagoon	11 Fuel storage	15 Oil well/Gas well
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	12 Fertilizer storage	16 Other (specify below)
			13 Insecticide storage	

Direction from well? **none open Field** How many feet? **500**

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
<b>0</b>	<b>10</b>	<b>clay</b>			
<b>10</b>	<b>13</b>	<b>sand</b>			
<b>13</b>	<b>15</b>	<b>clay</b>			
<b>15</b>	<b>20</b>	<b>sand</b>			
<b>20</b>	<b>22</b>	<b>clay</b>			
<b>22</b>	<b>44</b>	<b>fine sand</b>			
<b>44</b>	<b>46</b>	<b>clay</b>			
<b>46</b>	<b>52</b>	<b>dirty fine sand</b>			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <b>7-10-97</b> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <b>140</b> This Water Well Record was completed on (mo/day/yr) <b>7-15-97</b> under the business name of <b>Lynar Inc.</b> by signature <i>[Signature]</i>
---