

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Kingman	Township name	Fraction NE¹/₄NE¹/₄	Section number 20	Town number 29	Range number 9
Distance and direction from nearest town or city: 1 1/2 East-1/2 South of Willowdale, Ks.				3 Owner of well: H-30 Drilling Co.		
Street address of well location if in city:				Address: 200 North Main St. Wichita, Ks.		
Locate with "X" in section below:		Sketch map:				
N						
W						
S						
1 Mile						
2	Type and color of material	From	To	4 Well depth: 100 ft. Date of completion: 2-11-75 Well diameter: 8 in. 5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> Oil Field Water Supply 7 Casing: Material pvc Height: above /below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 4 in. to 60 ft. depth! Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No ___ in. to ___ ft. depth! Weight 160 lbs./ft.		
	Top soil	0	3	8 Screen: Manufacturer R & B Type pvc Dia. 4 Slot gauze 1/16 Length 20 Set between 60 ft. and 80 ft. Fittings: 3/4-3/8-1/16 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material CM-3		
	Sand	3	15	9 Static water level: 35 ft. below land surface Date 2-11-75 10 Pumping level below land surfaces: 50 ft. after 75 hrs. pumping 75 g.p.m. 1 hr. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 100 g.p.m.		
	Clay	15	15 1/2	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ___		
	Sand & gravel	15 1/2	31	12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 12 inches above grade		
	Clay & fine sand	31	46	13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> ___ Depth: From ___ ft. to ___ ft.		
	Clay	46	50	14 Nearest source of possible contamination: ft. 175 Direction South Type oil well Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
	Sand & gravel	50	77	15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
	Clay	77	100			
	Hard	100				
(use a second sheet if needed)						
16 Remarks: elevation well will be pulled & plugged				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. _____ Address Great Bend, Ks. Signed Fredia Dodson Date 2-17-75 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						