


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

SENT 7-14-77  
DAA

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Norton</b>	Township name <b>Emmett</b>	Fraction <b>NE 1/4 NE 1/4</b>	Section number <b>32</b>	Town number <b>2</b>	Range number <b>22 W</b>
Distance and direction from nearest town or city: <b>4 miles east of Norton</b>				3 Owner of well: <b>Vernon Heitman</b>		
Street address of well location if in city: <b>Norton</b>				Address: <b>RR1 Norton</b>		
Locate with "X" in section below: N  W E S 1 Mile		Sketch map:		4 Well depth: <b>71</b> ft. Date of completion <b>6-27-77</b> Well diameter <b>8</b> in.		
				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material <b>Plastic</b> Height: above/below <b>12</b> Cement <input checked="" type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> in. Diam. <b>5</b> in. to <b>21</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <b>5</b> in. to <b>—</b> ft. depth		
				8 Screen: Manufacturer: <b>Cood Plastic</b> Type: <b>Plastic</b> Dia. <b>5</b> Slot/gauze <b>.020</b> Length <b>70 FT</b> Set between <b>61</b> ft. and <b>71</b> ft. Fittings: <b>Small Road Gravel</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>—</b>		
2 Type and color of material				9 Static water level: <b>44 1/2 FT.</b> <b>44 1/2</b> ft. below land surface Date <b>6-27-77</b>		
				10 Pumping level below land surfaces: <del>44 1/2</del> ft. after <b>1</b> hrs. pumping <b>15</b> g.p.m. <b>50 1/2</b> ft. after <b>—</b> hrs. pumping <b>—</b> g.p.m. Estimated maximum yield <b>30</b> g.p.m. <b>FST</b>		
44.5' 73.5' salt brack				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <b>—</b>		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
14 Alluvium				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> <b>—</b> Depth: From <b>5</b> ft. to <b>10</b> ft.		
				14 Nearest source of possible contamination: ft. <b>150 ft</b> Direction <b>SE</b> Type <b>Sewer</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
(use a second sheet if needed)				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>—</b> Model number <b>—</b> HP <b>—</b> Volts <b>—</b> Length of drop pipe <b>—</b> ft. capacity <b>—</b> g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				16 Remarks: elevation <b>2325 (TOP)</b> <b>2150</b>		
16 Remarks: elevation				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief <b>Murphy Well Drilling 220</b> Business name <b>Boyle 05</b> License No. Address <b>—</b> Signed <b>Harry Murphy</b> Date <b>7-2-77</b> Authorized representative		

22 W 32 NE SE