


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

Sent 4-21-77 1 SECTION 12

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ADB

1. Location of well:		County NORTON	Fraction NW 1/4 SE 1/4 NE 1/4	Section number 14	Township number T 2 S R 23 W E 10	Range number	
2. Distance and direction from nearest town or city: 1 E 3 N Street address of well location if in city: NORTON			3. Owner of well: ROBERT MAPES JR. R.R. or street: Box 219 City, state, zip code: NORTON KANSAS				
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 20 in. Completion date 2-11-77 Well depth 107 ft.			
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
TOP SOIL		0	84	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
FINE SAND - MED GRAVEL SANDSTONE		84	90	9. Casing: Material Steel Height: <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 12 3/4 to 107 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. 174			
CLAY - FINE SAND - MED GRAVEL		90	95	10. Screen: Manufacturer's name WABROWN			
FINE SAND Med GRAVEL color		95	100	Type LUER Dia. 12 3/4 Slot/gauze 7/8 MN Length 20 Set between 87 ft. and 107 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 - 3/8			
FINE SAND Med GRAVEL SANDY CLAY		100	105	11. Static water level: _____ mo./day/yr. 77 ft. below land surface Date 2-1-77 MNC			
CLAY FINE SAND SANDY CLAY		105	110	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping 200 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 200 g.p.m.			
SANDY CLAY OCHR. - SHALE		110	115	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____			
112				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade			
77				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
35' sand thick				16. Nearest source of possible contamination: ft. _____ Direction _____ Type NONE Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
in Og				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ben Jay Drilling Co. 214 Business name _____ License No. _____ Address 24503 Colby Rd Signed Monty Ball Date 3-17-77 Authorized representative			
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: 7361 (TOPG) 112 22-91			20. Water well contractor's certification: (continued)			

1-2-3-4
1/4 1/4 1/4
NW SE NE
Sec