

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

DCC

Wagner

1. Location of well:	County Norton	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 21	Township number T 2 S R 24	Range number 24
2. Distance and direction from nearest town or city: Street address of well location if in city:	7 miles west 2 north of Norton KS		3. Owner of well: Virgil Wegener. R.R. or street: RR #3 City, state, zip code: Norton KS 67654		
4. Locate with "X" in section below:			Sketch map: 		
5. Type and color of material	From	To	6. Bore hole dia. 9 in. Completion date 3-23-78 Well depth 128 ft.		
CLAY, TAN	0	43	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
SANDSTONE & WHITE ROCK.	43	86	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
SAND, FINE.	86	93	9. Casing: Material _____ Height Above or below Threaded _____ Welded _____ Surface 12 in. RMP PVC <input checked="" type="checkbox"/> Weight 225 lbs./ft. Dia. 5 in. to 108 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 258		
RED SOAP STONE & GRAY ROCK	93	130	10. Screen: Manufacturer's name MODERN PIPES INC. Type PVC Dia. 5" Slot 0.070 Length 20' Set between 108 ft. and 128 ft. ft. and _____ ft. Gravel pack? YES Size range of material 1/4-1/4		
BROCK ?			11. Static water level: _____ mo./day/yr. 97 ft. below land surface Date 3-23-78		
140' sat			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 25 g.p.m.		
87'			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
43' col block			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
in Og			15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input checked="" type="checkbox"/> Depth: From 5 ft. to 15 ft.		
			16. Nearest source of possible contamination: ft. 150 Direction WEST Type SEWER Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. FAWCETT Drilling License No. 167 Business name _____ Address Box 149 Norton KS Signed A. Fawcett Date 4/12/78 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	2473 120 2343				

2
 24
 21
 SUS USE
 1/4 1/4 1/4 1/4