

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County <u>Republic</u>	Fraction <u>NE 1/4 SE 1/4 NE 1/4</u>	Section number <u>18</u>	Township number T <u>2</u> S	Range number R <u>4</u> E <u>W</u>
2. Distance and direction from nearest town or city: <u>2 1/2 S 1 E 1/4 S</u>			3. Owner of well: <u>Emerson Gritten</u>		
Street address of well location if in city: <u>of Republic, KS</u>			R.R. or street: City, state, zip code: <u>Republic KS 66964</u>		
4. Locate with "X" in section below:		Sketch map:			
N 1 Mile W E S 1 Mile					
5. Type and color of material		From	To		6. Bore hole dia. <u>8</u> in. Completion date <u>8-30-77</u> Well depth <u>60</u> ft.
<u>Top soil clay & silts</u>		<u>0</u>	<u>30</u>		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
<u>Sandy clay</u>		<u>30</u>	<u>50</u>		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
<u>Clay w/ broken rock & sand</u>		<u>50</u>	<u>56</u>		9. Casing: Material <u>Plst</u> Height: <u>Above or below</u> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>24</u> in. RMP <input checked="" type="checkbox"/> PVC Weight <u> </u> lbs./ft. Dia. <u>5</u> in. to <u>60</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>250</u>
<u>shale</u>		<u>56</u>	<u>60</u>		10. Screen: Manufacturer's name <u>Jet Stream</u> Type <u>Slatted Plst</u> Dia. <u>5"</u> Slot/gauze <u>0030</u> Length <u>101</u> Set between <u>46</u> ft. and <u>56</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <input checked="" type="checkbox"/> <u>yes</u> Size range of material <u>Fin. 30</u>
					11. Static water level: <u> </u> mo./day/yr. <u>31</u> ft. below land surface Date <u>8-30-77</u>
					12. Pumping level below land surfaces: <u>34</u> ft. after <u>1</u> hrs. pumping <u>15</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>30+</u> g.p.m.
					13. Water sample submitted: <u> </u> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u> </u>
					14. Well head completion: <u> </u> Pitless adapter <u>24</u> inches above grade
					15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>5</u> ft. to <u>16</u> ft.
					16. Nearest source of possible contamination: ft. <u>60</u> Direction <u>S</u> Type <u>Sewer</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: <u>1510'</u>	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>MARUHN Well Drilling 145</u> Business name License No. <u>68970</u> Address <u>Red Cloud Ne 68970</u> Signed <u>Leroy Maubach</u> Date <u>8-30-77</u> Authorized representative		

2
4
W
18
E
1/4
1/4
E
NESENE