

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Sumner	Township name London	Fraction 1/4 NE	Section number 1	Town number 30	Range number 1W
Distance and direction from nearest town or city: SE of town proper			3 Owner of well: Howard A. Dunnell			
Street address of well location if in city: 525 North C Peck, Ks.			Address: 525 North C Peck, Kansas			
Locate with "X" in section below:		Sketch map:		4 Well depth: 60 ft. Date of completion 7-26-75 Well diameter 11 in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material RMP Height: (above/below) _____ Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. _____ Weight 200 lbs./ft. Sked 5 in. to 60 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth!		
				8 Screen: Manufacturer J&L Type RMP Dia. 5" (lot) gauze _____ Length 10' Set between 50 ft. and 60 ft. _____ Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 3/8		
2		Type and color of material		From	To	9 Static water level: 16 ft. below land surface Date 8-28-75
		Overburden		0	5	10 Pumping level below land surfaces: 20 ft. after 1 hrs. pumping 30 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 40 g.p.m.
		Firm Reddish Clay		5	10	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
		Fine White Sand		10	30	12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> _____ <input type="checkbox"/> Inches above grade
		Coarse Sand		30	40	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 10 ft. to G.L. ft.
		1/8" White to Reddish				14 Nearest source of possible contamination: ft. 150 Direction N Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		Gravel		40	58	15 Pump: PUMPCO <input type="checkbox"/> Not installed Manufacturer's name Pumpco Model number 3526159P HP 1 1/2 Volts 230 Length of drop pipe 53 ft. capacity 35 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
		Dark Soft Shale		58	60	16 Remarks: elevation 1275 MSL Well is constructed as a Domestic, present use as an Irrigation only, Submersible Pump was installed wash out pressure Tank with SW disconnect in Tool House, a Snifter Valve installed in discharge line in Well below below Frost line
						17 Water well contractor's certification: 135A This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. B.C. Wilkinson Well Drilling 135 Business name _____ License No. _____ Address 1028 Ida Wichita, Ks. Signed B.C. Wilkinson Date 9-24-75 Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5