

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number	
County: SUMNER		SE 1/4 SE 1/4 NE 1/4		12		T 30 S		R 1 W E/W	
Distance and direction from nearest town or city?				Street address of well if located within city? 12121 So. Meridian					
2 WATER WELL OWNER: Greg Lassey									
RR#, St. Address, Box # : 2324 W. 79th St. So.						Board of Agriculture, Division of Water Resources			
City, State, ZIP Code : Wichita, Kansas						Application Number:			
3 DEPTH OF COMPLETED WELL: 65 ft. Bore Hole Diameter: 11 in. to ft., and in. to ft.									
Well Water to be used as:									
1 Domestic		3 Feedlot		5 Public water supply		8 Air conditioning		11 Injection well	
2 Irrigation		4 Industrial		6 Oil field water supply		9 Dewatering		12 Other (Specify below)	
				7 Lawn and garden only		10 Observation well			
Well's static water level: 21 ft. below land surface measured on 11 month 27 day 79 year									
Pump Test Data: Well water was ft. after hours pumping gpm									
Est. Yield gpm: Well water was ft. after hours pumping gpm									
4 TYPE OF BLANK CASING USED:									
1 Steel		3 RMP (SR)		5 Wrought iron		8 Concrete tile		Casing Joints: Glued X Clamped	
2 PVC		4 ABS		6 Asbestos-Cement		9 Other (specify below)		Welded	
				7 Fiberglass				Threaded	
Blank casing dia: 5 in. to 45 ft. Dia in. to ft. Dia in. to ft.									
Casing height above land surface: 12 in. weight lbs./ft. Wall thickness or gauge No. 200									
TYPE OF SCREEN OR PERFORATION MATERIAL:									
1 Steel		3 Stainless steel		5 Fiberglass		7 PVC		10 Asbestos-cement	
2 Brass		4 Galvanized steel		6 Concrete tile		8 RMP (SR)		11 Other (specify)	
						9 ABS		12 None used (open hole)	
Screen or Perforation Openings Are:									
1 Continuous slot		3 Mill slot		5 Gauzed wrapped		8 Saw cut .06		11 None (open hole)	
2 Louvered shutter		4 Key punched		6 Wire wrapped		9 Drilled holes			
				7 Torch cut		10 Other (specify)			
Screen-Perforation Dia: 5 in. to 65 ft. Dia in. to ft. Dia in. to ft.									
Screen-Perforated Intervals: From 45 ft. to 65 ft. From ft. to ft. From ft. to ft.									
Gravel Pack Intervals: From 14 ft. to 65 ft. From ft. to ft. From ft. to ft.									
5 GROUT MATERIAL:									
1 Neat cement		2 Cement grout		3 Bentonite		4 Other			
Grouted Intervals: From 40" ft. to 14 ft. From ft. to ft. From ft. to ft.									
What is the nearest source of possible contamination:									
1 Septic tank		4 Cess pool		7 Sewage lagoon		10 Fuel storage		14 Abandoned water well	
2 Sewer lines		5 Seepage pit		8 Feed yard		11 Fertilizer storage		15 Oil well/Gas well	
3 Lateral lines		6 Pit privy		9 Livestock pens		12 Insecticide storage		16 Other (specify below)	
						13 Watertight sewer lines			
Direction from well: Southwest How many feet: 65 ? Water Well Disinfected? Yes X No									
Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample									
was submitted month day year Pump Installed? Yes No X									
If Yes: Pump Manufacturer's name: Pump not installed at time HP Volts									
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.									
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other									
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was									
completed on 11 month 27 day 79 year									
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236									
This Water Well Record was completed on 6 month 12 day 1980 year under the business									
name of Harp Well & Pump Serv., Inc. by (signature) M. Arnold									
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:									
		FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG		
		0	2	Topsoil					
		2	12	Sandy Soil					
		12	18	Fine Sand					
		18	31	Fine Sand with Clay Streaks					
		31	39	Medium to Coarse Sand					
	39	65	Coarse Sand						
ELEVATION:									
Depth(s) Groundwater Encountered 1. 21 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)									
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.									

OFFICE USE ONLY

T 30

R 1

E/W

SEC. 12

SE 1/4 SE 1/4 NE 1/4