


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Sumner</b>	Fraction <b>1/4 SE 1/4 SE 1/4</b>	Section number <b>26</b>	Township number <b>T 30 S R 1W E/W</b>	Range number
2. Distance and direction from nearest town or city: <b>3 miles West of Belle Plaine Y and 1 1/2 miles North on the West side of the road.</b>			3. Owner of well: <b>D. L. Snyder</b> R.R. or street: <b>Rt. #1</b> City, state, zip code: <b>Belle Plaine, KS</b>		
4. Locate with "X" in section below: 			Sketch map: <b>Belle Plaine, Kansas</b>		
5. Type and color of material			From	To	6. Bore hole dia. <u>11</u> in. Completion date <u>11-10-78</u> Well depth <u>45</u> ft.
Topsoil			0	3	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay			3	10	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Fine sand			10	40	9. Casing: Material <u>Styrene</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC Weight _____ lbs./ft. Dia. <u>5</u> in. to <u>45</u> ft. depth Wall thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>.200</u>
Grey shale			40	45	10. Screen: Manufacturer's name _____ <b>Sunflower plastic</b> Type <u>styrene</u> Dia. <u>5"</u> Slot/bore <u>.06</u> Length <u>15'</u> Set between <u>30</u> ft. and <u>45</u> ft. _____ ft. and _____ ft. Gravel pack? <u>yes</u> Size range of material <u>1/2-1/8"</u>
					11. Static water level: _____ mo./day/yr. <u>15</u> ft. below land surface Date <u>11-10-78</u>
					12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
					13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input type="checkbox"/> Date _____
					14. Well head completion: _____ <input type="checkbox"/> Pitless adapter <u>12</u> capped _____ inches above grade
					15. Well grouted? <u>yes</u> <u>1-2</u> fine sand mix With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>40"</u> ft. to <u>14</u> ft.
					16. Nearest source of possible contamination: ft. _____ Direction _____ Type <u>None</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					(Use a second sheet if needed)
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	Flat ground Septic system not installed at this time.		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Harp Well &amp; Pump</b> 236 Business name License No. _____ Address <b>Wichita, Kansas</b> 67209 Signed <u>M. Arnold</u> Date <u>12-5-78</u> Authorized representative		

30 - 10 20 SE SE  
T  
R  
W  
E  
Sec  
1/4 1/4 1/4