

1. Location of well: County <u>KINGMAN</u>		Fraction <u>SE 1/4 NW 1/4 SW 1/4</u>	Section number <u>10</u>	Township number <u>T 30</u>	Range number <u>S R 10 W E/W</u>
2. Distance and direction from nearest town or city: <u>3 1/4 E 1/4 N OF NASHVILLE, KS</u>			3. Owner of well: <u>FRED DEPENBUSH</u>		
Street address of well location if in city:			R.R. or street:		
			City, state, zip code: <u>ZENDA, KS</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>30</u> in. Completion date <u>28 DEC 76</u>	
				Well depth <u>150</u> ft.	
5. Type and color of material		From	To	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
<u>GYP, WHITE HARD</u>		<u>0</u>	<u>9</u>	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
<u>SAND, FINE TO COARSE</u>		<u>9</u>	<u>15</u>	9. Casing: Material <u>STL</u> Height: <u>Above</u> or below	
<u>CLAY, GRAY & TAN HARD</u>		<u>15</u>	<u>30</u>	Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in.	
<u>SAND, COARSE & MED TO COARSE GRAVEL</u>		<u>30</u>	<u>73</u>	RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u> </u> lbs./ft.	
<u>CLAY, SANDY TAN</u>		<u>73</u>	<u>88</u>	Dia. <u>16</u> in. to <u>90</u> ft. depth Wall Thickness: inches or	
<u>SAND, FINE TO COARSE</u>		<u>88</u>	<u>115</u>	Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>188</u>	
<u>CLAY, SANDY TAN</u>		<u>115</u>	<u>120</u>	10. Screen: Manufacturer's name <u>WA BROWN</u>	
<u>SAND, FINE TO COARSE</u>		<u>120</u>	<u>150</u>	Type <u>FREEFLOW</u> Dia. <u>16</u>	
<u>SHALE, RED</u>		<u>150</u>	<u>160</u>	Slot gauze <u>1/8</u> Length <u>60</u>	
				Set between <u>90</u> ft. and <u>150</u> ft.	
				Gravel pack? <u>YES</u> Size range of material <u>1/2 - 1/8</u>	
				11. Static water level: <u>45</u> ft. below land surface Date <u>28 DEC 76</u>	
				12. Pumping level below land surfaces:	
				<u>80</u> ft. after <u>1</u> hrs. pumping <u>818</u> g.p.m.	
				<u>99</u> ft. after <u>1</u> hrs. pumping <u>1135</u> g.p.m.	
				Estimated maximum yield <u>1200</u> g.p.m.	
				13. Water sample submitted: <u> </u> mo./day/yr.	
				<u> </u> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u> </u>	
				14. Well head completion:	
				<u> </u> Pitless adapter <u> </u> inches above grade	
				15. Well grouted? <u>YES</u>	
				With: <u> </u> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete <input type="checkbox"/>	
				Depth: From <u>0</u> ft. to <u>10</u> ft.	
				16. Nearest source of possible contamination:	
				ft. <u> </u> Direction <u> </u> Type <u>None</u>	
				Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/>	
				17. Pump:	
				<u> </u> Not installed	
				Manufacturer's name <u>FLOWAY</u>	
				Model number <u>12 DOL</u> HP <u> </u> Volts <u> </u>	
				Length of drop pipe <u>100</u> ft. capacity <u>800</u> g.p.m.	
				Type:	
				<u> </u> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/>	
				<u> </u> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/>	
				<u> </u> Centrifugal <input type="checkbox"/> Other <input type="checkbox"/>	
18. Elevation:		19. Remarks:		20. Water well contractor's certification:	
Topography:		<u>A 5'x10' SLAB WAS POURED AT SURFACE</u>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
<input type="checkbox"/> Hill				<u>CENTRAL Well & Pump</u> <u>325</u>	
<input type="checkbox"/> Slope				Business name <u> </u> License No. <u> </u>	
<input checked="" type="checkbox"/> Upland				Address <u>121 S. TAYLOR PRATT</u>	
<input type="checkbox"/> Valley				Signed <u>E. E. E. E. E.</u> Date <u>1 FEB 77</u>	
				Authorized representative <u> </u>	