



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County KINSMAN	Township name LIBERTY	Fraction NW 4	Section number 16	Town number 30 5	Range number 10 W																																		
Distance and direction from nearest town or city: NASHVILLE KAN			3 Owner of well: Joe Strong																																					
Street address of well location if in city: HERY STREET			Address: Nashville Kansas 67112																																					
Locate with "X" in section below: 			Sketch map: W  WELL HOUSE SEPTIC TANK X			4 Well depth: 100 ft. Date of completion 2-4-76 Well diameter 8" in. BORE																																		
<table border="1"><thead><tr><th>2</th><th>Type and color of material</th><th>From</th><th>To</th></tr></thead><tbody><tr><td></td><td>TOP SOIL</td><td>0</td><td>1</td></tr><tr><td></td><td>Sand Yellowish Brown</td><td>1</td><td>10</td></tr><tr><td></td><td>Clay and Sand</td><td>20</td><td>20</td></tr><tr><td></td><td>White Clay Very Hard</td><td>30</td><td>40</td></tr><tr><td></td><td>Sand coarse Gravel</td><td>50</td><td>60</td></tr><tr><td></td><td>TOTAL Depth of Well</td><td></td><td></td></tr><tr><td></td><td>60 feet on Clay</td><td></td><td></td></tr><tr><td></td><td>Bottom</td><td></td><td></td></tr></tbody></table>			2	Type and color of material	From	To		TOP SOIL	0	1		Sand Yellowish Brown	1	10		Clay and Sand	20	20		White Clay Very Hard	30	40		Sand coarse Gravel	50	60		TOTAL Depth of Well				60 feet on Clay				Bottom			<input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
			2	Type and color of material	From	To																																		
				TOP SOIL	0	1																																		
				Sand Yellowish Brown	1	10																																		
				Clay and Sand	20	20																																		
	White Clay Very Hard	30	40																																					
	Sand coarse Gravel	50	60																																					
	TOTAL Depth of Well																																							
	60 feet on Clay																																							
	Bottom																																							
			6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> HUMAN CONSUMPTION																																					
			7 Casing: Material PLASTIC Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. Diam 5 in. to 60 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth																																					
			8 Screen: Manufacturer Jess & Lowell Type PVC Dia. 5" Slot/gauze 1/4 Length 20 feet Set between 40 ft. and 60 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4																																					
			9 Static water level: 20 ft. below land surface Date 2-4-76																																					
			10 Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after N/A hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.																																					
			11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 2-4-76																																					
			12 Well head completion: <input type="checkbox"/> Pitless adapter 24" <input type="checkbox"/> Inches above grade																																					
			13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> 2-4-76 Depth: From 1 ft. to 10 ft.																																					
			14 Nearest source of possible contamination: ft. 50 Direction NORTH Type HUMAN Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No																																					
			15 Pump: <input type="checkbox"/> Not installed Manufacturer's name STAY RITE Sub Model number LP20 HP 1/2 Volts 280 Length of drop pipe 42 ft. capacity 40 g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																					
16 Remarks: elevation			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. WEBER WELL Service 226 Business name _____ license No. _____ Address NASHVILLE KANSAS Signed George Weber Date 2-4-76 Authorized representative																																					