

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Ximmon</u>		Fraction <u>1/4 1/4 NW 1/4</u>		Section number <u>16</u>		Township number <u>T 30S</u>		Range number <u>R 10 W</u>	
2. Distance and direction from nearest town or city: <u>City of Nashville</u>				3. Owner of well: <u>HOLDIE HENSICK</u>					
Street address of well location if in city: <u>LOT 16-1718 BLOCK 11</u>				R.R. or street: <u>BOX 104 NASHVILLE KANSAS</u>					
				City, state, zip code: <u>67112</u>					
4. Locate with "X" in section below: N W SW SE S 1 Mile				Sketch map: <u>N</u> <u>well X</u> <u>House</u> <u>S</u>		6. Bore hole dia. <u>8</u> in. Completion date <u>9-8-77</u> Well depth <u>60</u> ft.			
						7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
						8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
						9. Casing: Material <u>PVC</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>2 Feet</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u> </u> lbs./ft. Dia. <u>5</u> in. to <u>60</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>14</u>			
5. Type and color of material				From		To		10. Screen: Manufacturer's name <u>John & Lowell</u>	
<u>Top Soil</u>				<u>0</u>		<u>1</u>		Type <u>PVC</u> Dia. <u>5"</u>	
<u>White Silty Clay</u>				<u>1</u>		<u>20</u>		Slot/gauze <u>5/16</u> Length <u>10 feet</u>	
<u>Sand Brown</u>				<u>20</u>		<u>30</u>		Set between <u>50</u> ft. and <u>60</u> ft.	
<u>Blue Clay and Sand</u>				<u>40</u>		<u>50</u>		Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4</u>	
<u>Sand Coarse Gravel</u>				<u>50</u>		<u>60</u>		11. Static water level: <u>30</u> ft. below land surface Date <u>9-8-77</u>	
<u>TOTAL Dept 60 feet Bottom</u>								12. Pumping level below land surfaces: <u> </u> ft. after <u>1 hr</u> pumping <u> </u> g.p.m. <u> </u> ft. after <u>hrs.</u> pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.	
<u>of Well. Clay</u>								13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u>9-8-77</u>	
								14. Well head completion: <u>well House</u> <u> </u> Pitless adapter <u>2 feet</u> inches above grade	
								15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>1</u> ft. to <u>10</u> ft.	
								16. Nearest source of possible contamination: ft. <u>60</u> Direction <u>East</u> Type <u>HUMAN</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
								17. Pump: <u>Not installed</u> Manufacturer's name <u>Burks</u> Model number <u>1045</u> HP <u>5</u> Volts <u>110</u> Length of drop pipe <u>40</u> ft. capacity <u>15</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input checked="" type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
								20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Walter Well Service</u> <u>226</u> Business name License No. Address <u>Nashville Kan</u> Signed <u>Don G. Webb</u> Date <u>9-8-77</u> Authorized representative	
18. Elevation:		19. Remarks: <u>Concrete slab to be installed</u> <u>by customer at surface of</u> <u>ground 4x4 Slab and well House</u>							