## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

[ · · · · · · · · · · · · · · · · · · ·	County	Fraction		Section	number	Township number	Range number	
1. Location of well:	Kingman	1/4 1/4 N	W1/4	/4 20		т 30 s		
2. Distance and direction from nearest town or city: / Mile West Street address of well location if in city: 4 / Mile South R.R. or City, st						Fred Depenbusch Zenda, Kansas		
4. Locate with "X" in section below:  N						6. Bore hole dia. 30 in. Completion date Well depth 167 ft.		
Well No. 1 (TH 1				-76)		7 Cable tool Rotary Driven Dug Hollow rod Jetted Bored X Reverse rotary		
E S S S S S S S S S S S S S S S S S S S						8. Use: Domestic Public supply Industry  X		
						9. Casing: Material St.1 Height: Above the street of the s		
5. Type and color of material				From	То	Dia.16 in. to 123t. dep Dia in. to ft. dep		
Sandy goil				0	2	10. Screen: Manufacturer's metal Proc	ducts Co.	
Sandy soil					7	Slot/gauze ====================================	Dia. 16" Length 44'	
Fine to coarse sand				7	10	Set betweenft. c	andft.	
Clay				10	34	Gravel pack? X Size ra  11. Static water level:	mo./day/yr.	
Med. to coarse sand & gravel				34	45	12. Pumping level below land	d surfaces:	
Clay				<b>4</b> 5	62		hrs. pumpingg.p.m.	
Med. to coarse sand & gravel				62	76	13. Water sample submitted:		
Clay				76	90	14. Well head completion:	Date	
Med. to coarse sand & gravel				90	94	Pitless adapter  15. Well grouted?	12 Inches above grade	
Clay				94	125	With: Neat cement Depth: From ft. to	Bentonite Concrete	
Med. to coarse sand & gravel w/some cla				125	150	16. Nearest source of possible		
Clay				150	157	Well disinfected upon comple 17. Pump:	Not installed	
Med. to coarse sand & gravel				157	166	Manufacturer's name La' Model number		
Shale				166		Length of drop pipe 100 Type:	_ ft. capacity a g.p.m.	
	// / .l.	neat if people!\				Submersible Jet Centrifugal	Turbine Reciprocating Other	
(Use a second sheet if needed)  18. Elevation: 19. Remarks:					L	20. Water well contractor's	certification:	
Tanamak						This well was drilled under m is true to the best of my know	ledge and belief.	
Topography:  —— Hill						Layne Western Co. 102 Business name  Address Wickliff Kansas		
Slope Upland Valley						Signed -	Mansas  Date 2/9/7	