WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1 1	County	Fraction	Section	number	Township number	Range number	
1. Location of well:	Kingman	SE1/4NW/4NE1/4		31.	т 30 s		E/W
2. Distance and direction from near fit town or city: 35 & 14 W 3. Owner of well: Levie Hellman NO.Z							
Street address of well location if in city: of Maskville City, state, zip code: Maskville, Ka							
4. Locate with "X" in section below: Sketch map:					6. Bore hole dia. 30 in. Completion date		
					7Cable toolRotary Driven Dug		
					B. Use: Domestic Public supply Industry		
					Irrigation Air conditioning Stock		
SW SE					Lawn Oil field water Other 9. Casing: Material STC Height: Above or below		
Li i i					Threaded Welded _X Surface in . RMP PVC Weight lbs ./ft .		
ı ← 1 Mile — → ı					Dia 16 in. to 33 ft. depth Wall Thickness: inches or		
5. Type and color of material				То	Dia in. to ft. dept 10. Screen: Manufacturer's n		
Soil, sandy				2	Type	Dia. 16"	
Clay, tan				7	Slot/gauze	Length	
Sand, coarse and coarse gravel			7	14	Gravel pack? Size rai	nd	ft.
Clay, tan, sandy			14	19	11. Stațic water level:	що./de	gy/yr.
Sand, fine to coarse and med. gravel				32	ft. below land sur	17	
)2	35 ft. after 2 ft. after 2 ft.	rs. pumping #05 g	
Clay, tan				34	Estimated maximum yield	750 g	.p.m.
Sand, fine to coarse and fine to coarse gravel				43	13. Water sample submitted: Yes X No	mo./do	ay/yr.
Sand, with clay streaks				46	14. Well head completion:	12	
Sand, fine to coarse and fine to med, gravel				53	Pitless adapter 15. Well grouted? X	12 Inches above gra	ide
Clay, gray				60	With: Neat cement X Bentonite Concrete Depth: From ft. to ft.		
					16. Nearest source of possible	•	
					Well disinfected upon comple		No I
					17. Pump: Manufacturer's name	X Not installed	
					Model number	HP Volts	— ' <u> </u>
					Length of drop pipe Type:	. , ,	.p.m. *
					Submersible Jet	Turbine Reciprocat	ting
(Use a second sheet if needed)					Centrifugal	Other	
18. Elevation: 19. Remarks: 5' X 10' X 8' slab poured Topography: Hill Slope Slope					20. Water well contractor's of This well was drilled under my	jurisdiction and this rep	port
Topography:					is true to the best of my know Central Well &	_	325 ≩ <u>\$</u>
HIII at Surface				Business name	Pump Svc Licens vlor Pratt K	e No.	
Upland Valley					Signed Authorized repr	wife Date -	
orward the white, blue and pink copies to the Department of Health and Environment Authorized representative Authorized representative Authorized representative Authorized representative Form WWC-5							