

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County BARBER	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 1	Township number T 30 S	Range number R 11 W E/W
2. Distance and direction from nearest town or city: 2N 2W of Nashville, Rs				3. Owner of well: BOSSIE KRUCKENBURG		
Street address of well location if in city: Nashville, Rs				City, state, zip code: ISABEL, KS		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 19 mar 79		
<div style="text-align: center;">N</div> <div style="text-align: center;">S</div>				Well depth 150 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material STL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 90 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188		
5. Type and color of material				From	To	10. Screen: Manufacturer's name WABROWN
Soil				0	2	Type <input type="checkbox"/> Dia. 16"
Sand, fine				2	6	Slot/gauze VR Length 60'
Clay, gray & tan				6	39	Set between 90 ft. and 150 ft.
Sand, fine to coarse & fine gravel				39	48	Gravel pack? <input checked="" type="checkbox"/> Size range of material 4x8
Clay, tan				48	54	11. Static water level: 35 ft. below land surface Date 19 mar 79
Sand, fine to coarse & coarse gravel				54	66	12. Pumping level below land surfaces: 51 ft. after 1 hrs. pumping 800 g.p.m. 54 ft. after 1 hrs. pumping 1000 g.p.m. Estimated maximum yield 1600 g.p.m.
Clay, gray & white				66	70	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
Sand, fine to coarse & med gravel				70	82	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
Clay, gray & white				82	97	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Sand, fine to coarse & med gravel				97	134	16. Nearest source of possible contamination: NONE ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Sand, fine to coarse & coarse gravel				134	150	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Simmons Model number <input type="checkbox"/> HP 60 Volts <input type="checkbox"/> Length of drop pipe 120 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Shale, Red				150	160	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump 325 Business name Box 1032 Pratt KS License No. <input type="checkbox"/> Address Box 1032 Pratt KS Signed KB Honomickl Date 5 Apr 79 Authorized representative
18. Elevation:				19. Remarks: 5' X 10' X 8" Concrete Slab poured at Surface		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5