

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Barber	Fraction SE 1/4 NW 1/4 SE 1/4	Section number 2	Township number T 30 S R 11 W E/W	Range number
2. Distance and direction from nearest town or city: 4 E & 3 S of Isabel			3. Owner of well: Dale Tucker R.R. or street: City, state, zip code: Lawrence, KS			
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"> <div style="text-align: center; margin-right: 20px;"> </div> <div style="text-align: center;"> <p>Sketch map:</p> </div> </div>			6. Bore hole dia. 30 in. Completion date 18 July 77 Well depth 176 ft.			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
From			9. Casing: Material 376 Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 176 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188			
			10. Screen: Manufacturer's name Brown & Cook Type fuller Dia. 16" Slot/gauze 125 & 106 Length 60' Set between 116-166 ft. and 166-176 ft. Gravel pack? Yes Size range of material 1/2 X 3/4			
Soil			0	2	11. Static water level: 49 ft. below land surface Date 18 July 77	
Clay, brown, green & gyp & sand			2	59	12. Pumping level below land surfaces: 85 ft. after 1 hrs. pumping 800 g.p.m. 94 ft. after 1 hrs. pumping 1190 g.p.m. Estimated maximum yield 1400 g.p.m.	
Sand, fine - med hard			59	68	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
Sand, fine to coarse & med to coarse gravel			68	95	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
Clay, tan			95	97	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Sand, fine to coarse & med gravel - loose			97	102	16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type None Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Clay, tan			102	109	17. Pump: Manufacturer's name Simmons Model number <input type="checkbox"/> HP 80 Volts <input type="checkbox"/> Length of drop pipe 100 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Sand, fine to coarse			109	112	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump 325 Business name License No. Address 121 S. Taylor Pratt Signed John S. Taylor Date 18 July 77 Authorized representative	
Clay, gray & cemented sand			112	117		
Sand, fine to coarse - med loose			117	126		
Sand, fine to coarse w/ med gravel streaks			126	160		
Clay, red & white - hard			160	165		
Sand, fine to coarse & med gravel			165	176		
Shale, Red			176	180		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: 8' x 12' x 8" slab poured at surface				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5